
Advanced Methods of PID Controller Tuning for Specified Performance

Štefan Bucz and Alena Kozáková

Additional information is available at the end of the chapter

<http://dx.doi.org/10.5772/intechopen.76069>

Abstract

This chapter provides a concise survey, classification and historical perspective of practice-oriented methods for designing proportional-integral-derivative (PID) controllers and autotuners showing the persistent demand for PID tuning algorithms that integrate performance requirements into the tuning algorithm. The proposed frequency-domain PID controller design method guarantees closed-loop performance in terms of commonly used time-domain specifications. One of its major benefits is universal applicability for both slow and fast-controlled plants with unknown mathematical model. Special charts called B-parabolas were developed as a practical design tool that enables consistent and systematic shaping of the closed-loop step response with regard to specified performance and dynamics of the uncertain controlled plant.

Keywords: PID controller tuning, robust performance indices, B-parabolas, closed-loop, performance assessment, robust performance

1. Introduction

How to tune a controller for any control application quickly and appropriately? This question raised in 1942 is still up to date and constantly occupies the automation community worldwide. The answer is very intricate; its intricacy is comparable with the open hitherto unresolved Hilbert problems known from mathematics.

Will the PID controllers, historically the oldest but currently still the most used ones, control industrial processes in the near and far future? Based on the increase of the number of PID tuning methods from 258 to 408 during 2000–2005, a positive response can be assumed [23].

The remarkably simple ability of the PID controller to generate a difference equation using the present, past and future values of the control error is often projected into the philosophical understanding [1] and forecast this controller a long-term perspective.

Beginnings of PID controllers date back to 1935 when the Taylor Instruments Companies launched their pneumatic controller with a derivative channel [1]. Owing to rapid developments in the control theory, it was supposed that the conventional PID controllers would be gradually replaced by advanced ones; however, this did not come to pass mainly due to the simple PID structure and its commercial usability in practice. For 83 years, control loop designers preferred the PID controllers for their outstanding ability to eliminate the control error using the integrator, their ability to improve the performance using the “trend” of the controlled variable through the derivative channel and for many other benefits. PID controllers are important parts of distributed control systems, predictive control structures; their coefficients are often adapted by means of fuzzy and neural control and set by genetic algorithms [20, 21, 35]. In multiloop control structures, they are able to stabilize unstable objects and difficult-to-control systems. The 46 existing PID variants and reported 408 diverse tuning methods are a good prerequisite for achieving a satisfactory performance in simple as well as demanding industrial applications [23, 25].

PID controllers are widely applied in technological processes of heavy and light industries, for example in control of tension in the roll during paper winding, boiler temperature, chemical reactor pressure, lathe spindle position in metalworking, and so on; they can be found in modern cars controlling combustion control or vehicle dynamics [9], valve opening and robotic arm position. In the interconnected power system, they are used to control turbine power and speed in both primary and secondary regulation of active power and network frequency. Being easy to implement on both Arduino and Raspberry Pi platforms allows them to be used in mobile “unplugged” applications as well.

Commercial applicability of PID controllers is confirmed by studies referring that more than 90% out of all installed controllers in industrial control loops are PID controllers [36]. The alarming fact, however, is that only 20% of them are tuned correctly, and in 30% of all PID applications, the regulation is unsuitable due to an incorrect selection of synthesis method. Another 30% of poor performance is due to ignorance of nonlinear properties of actuators, and the remaining 20% represent an inadequate choice of sampling period or poor signal filtering [5]. Some controllers not only do not provide the required performance yet often even stability of the control loop being operated only in open loop and manually switched off by the service staff when approaching the setpoint [9]. According to other statistics, 30% of controllers operate in manual mode and require continuous fine-tuning and supervising by the process technologist. A 25% of PID applications use coefficients pre-set by the manufacturer with no update of their values with respect to the particular process [47].

Therefore, a natural requirement for innovative PID tuning methods has come up to ensure the specified performance [19, 22] in terms of the maximum overshoot and settling time not only for processes with constant parameters but for their perturbed types. In this chapter, a novel original robust PID tuning method is presented; hopefully, it will help reverse the above mentioned unfavorable statistics of incorrectly tuned PID controllers.

2. PID controller design for industrial processes for performance

Despite the fact that there are more than 11,000 PID controllers in 46 variants operating in industrial processes [23], mostly three basic forms are used to control industrial processes: the ideal (textbook) PID controller, the real PID controller with derivative filter, and the ideal PID controller in series with the first-order filter given by the following transfer functions, respectively.

$$G_R(s) = K\left(1 + \frac{1}{T_i s} + T_d s\right), \quad G_R(s) = K\left(1 + \frac{1}{T_i s} + \frac{T_d s}{1 + \frac{T_d}{N} s}\right), \quad G_R(s) = K\left(1 + \frac{1}{T_i s} + T_d s\right)\left(\frac{1}{T_f s + 1}\right), \quad (1)$$

where K is the proportional gain, T_i and T_d are the integral and the derivative time constants, respectively, T_f is the filter time constant and $N \in \langle 8, 16 \rangle$ in practical applications [37, 38]. The PID controller design objectives are:

1. tracking of setpoint or reference variable $w(t)$ by $y(t)$,
2. rejection of disturbance $d(t)$ and noise $n(t)$ influence on the controlled variable $y(t)$.

Time response of the controlled variable $y(t)$ is modifiable by parameters K , T_i and T_d , respectively; the objective is to achieve a zero steady-state control error $e(t)$ irrespective if caused by changes in the reference $w(t)$ or the disturbance $d(t)$. This section presents practice-oriented PID controller design methods based on various performance criteria.

Consider the control loop in **Figure 1** with control action $u(t)$ generated by the PID controller (switch SW in position “1”).

A controller design is a two-step procedure consisting of controller structure selection (P, PI, PD or PID) followed by tuning coefficients of the selected controller type.

2.1. PID controller structure selection

An appropriate structure of the controller $G_R(s)$ is usually selected with respect to:

- zero steady-state error condition ($e(\infty) = 0$),
- type of the controlled plant,
- parameters of the controlled plant.




Figure 1. Feedback control loop with load disturbance $d(t)$ and measurement noise $n(t)$.

2.1.1. PID controller structure selection based on zero steady-state error condition

Consider the unity feedback control loop (**Figure 1**), where $G(s)$ is the controlled system. According to the final value theorem, the steady-state error

$$e(\infty) = \lim_{s \rightarrow 0} sE(s) = \lim_{s \rightarrow 0} s \frac{1}{1+L(s)} W(s) = q! w_q \lim_{s \rightarrow 0} \frac{s^{v-q}}{s^v + K_L} \quad (2)$$

is zero if the integrator orders $v_L = v_S + v_R$ in the open-loop $L(s) = G(s)G_R(s)$ is greater than the order q of the reference signal $w(t) = w_q t^q$, i.e.,

$$v_L > q, \quad (3)$$

where v_S and v_R are integrator orders of the plant and the controller, respectively, K_L is the open-loop gain and w_q is a positive constant [46].

2.1.2. PID controller structure selection based on the plant type

Industrial process variables (e.g., position, speed, current, temperature, pressure, humidity, level) are commonly controlled using PI controllers; in practice, the derivative part is usually switched off due to measurement noise. For pressure and level control in gas tanks, using a P-controller is sufficient [3]. However, adding the derivative part improves closed-loop stability and steepens the step response rise time.

2.1.3. PID controller structure selection based on plant parameters

Consider the FOPDT ($j = 1$) and FOLIPDT ($j = 3$) plant models, respectively given as $G_{\text{FOPDT}} = K_1 e^{-D_1 s} / [T_1 s + 1]$ and $G_{\text{FOLIPDT}} = K_3 e^{-D_3 s} / \{s[T_3 s + 1]\}$ with the parameters given as follows:

$$\mu_1 = \frac{D_1}{T_1}; \quad \vartheta_1 = K_1 K_c; \quad \mu_3 = \frac{D_3}{T_3}; \quad \vartheta_3 = \frac{\lim_{s \rightarrow 0} sG(s)}{\omega_c |G(j\omega_c)|} = \frac{T_c K_3 K_c}{2\pi}; \quad \mu_3 = \frac{\frac{2}{\pi} + \arctg \sqrt{\vartheta_3^2 - 1}}{\sqrt{\vartheta_3^2 - 1}}, \quad (4)$$

where K_c and ω_c are critical gain and critical frequency of the plant, respectively, the normalized time delay μ_j , and the parameter ϑ_j can be used to select appropriate PID control strategy. According to **Table 1** [46], the derivative part is not used in presence of intense noise and a PID controller is not appropriate for plants with large time delays.

2.2. Performance measures in PID controller design

Performance measures for industrial control loops can be expressed both in the time and the frequency domains. The time-domain performance indicators allow to directly expressing the desired process parameter, whereas the frequency-domain performance indicators can be used as PID tuning parameters.

Ranges for μ and ϑ	Control strategy			
	No precise control necessary	Precise control needed		
		High noise	Low saturation	Low measurement noise
$\mu_1 > 1; \vartheta_1 < 1.5$	I	I + B + C	PI + B + C	PI + B + C
$0.6 < \mu_1 < 1; 1.5 < \vartheta_1 < 2.25$	I or PI	I + A	PI + A	(PI or PID) + A + C
$0.15 < \mu_1 < 0.6; 2.25 < \vartheta_1 < 15$	PI	PI	PI or PID	PID
$\mu_1 < 0.15; \vartheta_1 > 15$ or $\mu_3 > 0.3; \vartheta_3 < 2$	P or PI	PI	PI or PID	PI or PID
$\mu_3 < 0.3; \vartheta_3 > 2$	PD + E	F	PD + E	PD + E

A: forward compensation suggested, B: forward compensation necessary, C: dead-time compensation suggested, D: dead-time compensation necessary, E: set-point weighting necessary, F: pole-placement.

Table 1. Controller structure selection with respect to plant model parameters.




Figure 2. Performance measures: δ_{DR} , t_s , η_{max} and $e(\infty)$; (a) setpoint step response; (b) load disturbance step response; (c) over-, critically- and underdamped closed-loop step-responses.

2.2.1. Performance measures in the time-domain

In the time-domain, satisfactory setpoint tracking (**Figure 2a**) and disturbance rejection (**Figure 2b**) are indicated by small values of maximum overshoot and a decay ratio, respectively, given as

$$\eta_{max} = 100 \frac{|y_{max} - y(\infty)|}{y(\infty)} [\%]; \delta_{DR} = \frac{A_{i+1}}{A_i}, \tag{5}$$

where $y(\infty)$ denotes the steady-state value of $y(t)$ [4]. A measure of the $y(t)$ response decay is the ratio of two successive amplitudes A_{i+1}/A_i , where $i = 1 \dots N$, and N is half the number of points of intersections of $y(\infty)$ and $y(t)$. The settling time t_s is the time after which the output $y(t)$ remains within $\pm \epsilon\%$ of its final value (**Figure 2b**); typically $\epsilon = [1\%+5\%]y(\infty)$, $\delta_{DR} \in (1:4; 1:2)$,

$\eta_{\max} \in (0\%, 50\%)$. **Figure 2c** depicts underdamped (plot 1), overdamped (plot 2) and critically damped (plot 3) closed-loop step responses.

2.2.2. Performance measures in the frequency-domain

The most frequent parameters for PID tuning are the following performance measures [1]:

- ϕ_M and G_M : phase and gain margins, respectively,
- M_s and M_t : maximum peaks of magnitudes of the sensitivity function $S(j\omega)$ and complementary sensitivity function $T(j\omega)$, respectively,
- λ : required closed-loop time constant.

If a designed controller $G_R(j\omega)$ guarantees, that $|S(j\omega)|$ or $|T(j\omega)|$ do not exceed prespecified values M_s or M_t , respectively, defined by

$$M_s = \sup_{\omega} |S(j\omega)| = \sup_{\omega} \left| \frac{1}{1 + L(j\omega)} \right|; \quad M_t = \sup_{\omega} |T(j\omega)| = \sup_{\omega} \left| \frac{L(j\omega)}{1 + L(j\omega)} \right| \quad (6)$$

for $\omega \in (0, \infty)$, then the Nyquist plot of the open-loop transfer function $L(s) = G(s)G_R(s)$ avoids the respective circles M_s or M_t each given by its center and radius as follows:

$$C_s = [-1, j0], R_s = \frac{1}{M_s}; \quad C_t = \left[-\frac{M_t^2}{M_t^2 - 1}, j0 \right], R_t = -\frac{M_t}{|1 - M_t^2|}. \quad (7)$$

By avoiding the Nyquist plot of $L(s)$ to enter the circles corresponding to M_s or M_t , a safe distance from the critical point is kept (**Figure 3a**). Typical $|S(j\omega)|$ and $|T(j\omega)|$ plots for properly designed controller are in **Figure 3b**. The disturbance $d(t)$ is sufficiently rejected if




Figure 3. (a) Definition and geometrical interpretation of ϕ_M and G_M in the complex plane; (b) sensitivity and complementary sensitivity magnitudes $|S(j\omega)|$, $|T(j\omega)|$ and performance measures M_s , M_t .

$M_s \in (1.2; 2)$. The reference $w(t)$ is properly tracked by the process output $y(t)$ if $M_t \in (1.3; 2.5)$. With further increasing of M_t the closed-loop tends to be oscillatory.

From **Figure 3a** results, that by increasing open-loop phase margin ϕ_M the gain crossover $L(j\omega_a^*)$ on the unit circle M_t moves away from the critical point $(-1, j0)$; similarly by increasing open-loop gain margin G_M the phase crossover $L(j\omega_f^*)$ moves away from $(-1, j0)$. Therefore, the stability margins ϕ_M or G_M given by

$$\phi_M = 180^\circ + \arg L(j\omega_a^*); \quad G_M = \frac{1}{|L(j\omega_f^*)|} \quad (8)$$

are frequently used performance measures, their typical values are $\phi_M \in (20^\circ; 90^\circ)$, $G_M \in (2; 5)$. Relations between individual stability margins and respective magnitude peaks are given by the following inequalities

$$\phi_M \geq 2 \arcsin \left(\frac{1}{2M_s} \right); \quad \phi_M \geq 2 \arcsin \left(\frac{1}{2M_t} \right); \quad G_M \geq \frac{M_s}{M_s - 1}; \quad G_M \geq 1 + \frac{1}{M_t}. \quad (9)$$

The point in which the Nyquist plot $L(j\omega)$ touches the M_T circle defines the closed-loop resonance frequency ω_{Mt} .

2.3. PID controller design methodologies for performance

When synthesizing a control loop, if the controller type is already known and the designer has just to select a suitable method to appropriately adjust its coefficients, we speak about *PID controller tuning methods*. *Controller design* is a more complex problem which includes determining controller structure and then calculating its parameters. When setting coefficients of industrial PID controllers $\{K, T_i, T_d\}$, basically the following procedures are applied:

1. *Trial-and-error methods* are based on closed-loop experiments [1]. Controller parameters settings are based on observation of the response to reference or disturbance changes with the assistance of an expert, or the design is driven by empirical rules. The control-loop synthesis is time-consuming and its success is not guaranteed.
2. *Analytical methods* are used to generate a control law based on the mathematical model of the plant; the plant model is obtained from first principles or via experimental identification. The success of these methods depends on the accuracy of the mathematical model of the plant, and is not always achievable in practical cases (e.g., for a cement kiln).
3. *Classical tuning* methods use only a limited number of characteristic parameters of the plant obtained from the step response or critical system parameters [11, 27, 31]. Their main advantage is a simple and short calculation of controller parameters. The control objective is to provide a satisfactory response to reference change, or disturbance rejection and often their combination. The main drawback is that the designer cannot influence the performance by means of the adjustable parameters of the algorithm. Also, the resulting closed-loop response may not be satisfactory if the step response of the plant is nonmonotonic, or

when the plant has nonminimum-phase dynamics or large time delay. Most of these methods are implemented in autotuners of industrial PID controllers [1].

4. *Autotuners* are a modern and convenient means for adjusting coefficients of industrial controllers [33, 34, 49]. They implement a two-step algorithm of automatic acquisition of characteristic parameters of the controlled process followed by automatic calculation and adjustment of the controller coefficients. After activating the autotuning function on the industrial controller, the control-loop synthesis is performed automatically in a very short time. The ABB, Emerson, Fischer-Rosemont, Foxboro, Honeywell, Siemens, Yokogawa, or ZPA controllers have a built-in PID autotuning function implemented on a microcomputer [47]. In many situations, however, these methods are unreliable because of the imperfection of the plant identification algorithm and the subsequent controller design.
5. *Robust PID controller tuning methods for specified performance* represent a modern area of industrial control-loop synthesis. They improve the PID tuning methods by providing stability and required performance also for processes with variable parameters. The controller tuned only by conventional method is just “intuitively” invariant against perturbations of the controlled plant; robust operation of the control loop is usually possible only for small changes of plant parameters. The major disadvantage of these methods is that the control law is not based on the knowledge of uncertainties of the controlled object and a further research on their possible expansion is needed. The proposed original method which eliminates this drawback, its theoretical analysis and verification on benchmark examples are the core of the chapter.

2.4. PID controller tuning methods for performance

Tuning methods are commonly used engineering tool for the synthesis of industrial control loops as they do not require a full knowledge of the mathematical description of the controlled plant. This differentiates them from analytical methods which, on the contrary are based on a precise knowledge of the mathematical model of the controlled system. In the tuning methods, the controlled process is considered as a black-box ① which is to be revealed only to such extent that the controller synthesis is successful and the control objectives ② are achieved. Thus, only those characteristic parameters ③ of the unknown plant have to be acquired via appropriate identification ④ that are inevitable for the PID controller design. In this way, the PID controller ⑤ coefficients can be obtained in a relatively short time. The implicit knowledge about the controlled system ⑥ and the ambient influences affect the choice of the PID coefficients calculation method ⑦. According to the way of using the identified data of the controlled plant, the tuning methods are classified into as follows:

- a. model-free PID controller tuning methods,
- b. model-based PID controller tuning methods.

Percentage proportions of commonly used PID controller tuning methods are presented in **Figure 4**.

Approximately 12% out of all tuning methods are model-free methods, 88% (app. seven times more) are model-based ones. A 37% portion belongs to PID controllers of FOLPDT (first order




Figure 4. Percentages of commonly used PID controller tuning methods.

lag plus dead time) system models which are the most commonly used approximation of plant dynamics in industries (thermal plants, chemical and woodworking industries). Equal 9% shares belong to IPDT (integral plus dead time) and FOLIPDT (first order lag integral plus dead time) models with integral behavior encountered mainly in drives and power industry in modeling mechanical subsystems of rotating machines, valves and servo-systems and 18% of algorithms are used to control plants with SOSPDT (second order system plus dead time) models [26]. Controllers for other system types are tuned by methods from the 15% portion.

2.4.1. Model-free PID controller tuning with guaranteed performance

There are such PID tuning algorithms, which can be applied without any knowledge about the unknown plant model. These methods yielding PID coefficients for systems with a general, unknown model are known as “Non-Model Specific”, “Model-Free” or “Rule-Based” Methods. Their basic feature is that the identified characteristic parameters of the unknown system appear directly in the PID coefficient tuning rules. They are very popular among practitioners due to a high flexibility and ability to control a wide class of systems. The respective algorithms have been tested on benchmark examples, the control objectives can be expressed by empirical rules. They are simply algorithmizable for application in industrial autotuners. A seven-step flow diagram of a direct tuning method is depicted in Figure 5.

The oldest direct-type engineering method is the well-known Ziegler-Nichols frequency method (1942) [48]. The control objective ⑤ is a rapid disturbance rejection so that each amplitude of the oscillatory response to disturbance step change is only a quarter of the previous amplitude. The method is based on two identified ② characteristic parameters ① of the unknown plant βT_d : the critical frequency $\omega_c = 2\pi/T_c$ and the critical gain K_c used for calculation of the coefficients of P, PI and PID controllers ⑦. The first characteristic parameter provides basic information on plant dynamics, while the value of the second parameter indicates the degree-of-stability of the plant. PID controller parameters according to the Ziegler-Nichols method are calculated using the algorithm ⑥ $P_{ZN} = 0.6K_c$, $T_{iZN} = 0.5T_c = \pi/\omega_c$, $T_{dZN} = 0.125T_c = 0.25\pi/\omega_c$ in which the characteristic parameters $\{K_c, \omega_c\}$ are directly included.




Figure 5. Flow chart of the direct engineering PID tuning method.

2.4.1.1. Trial-and-error tuning methods

When first PID controllers were developed in the period 1935–1942, no tuning methods were available at the market. The controller “design” consisted in experimenting with control loops without considering any relationship between plant parameters and controller coefficients. Acquired experience, however, was generalized giving rise to empirical trial-and-error tuning method that consist of three main steps:

1. Turning off the integral and derivative parts of the PID controller and increasing the gain until the closed-loop oscillates with constant amplitudes, then adjusting the gain at half of this value.
2. Decreasing the integral time until oscillations with constant amplitude are obtained, then adjusting the integral time at a treble of this value.
3. Increasing the derivative time until oscillations with constant amplitude are obtained, then adjusting the derivative time at a third of this value.

The set of these rules of thumb is still being used in practice to roughly tune industrial PID controllers and is considered as a predecessor of all engineering tuning methods. In 1942, two direct tuning methods were published and authored by Ziegler and Nichols [48], employees of the Taylor Instrument Companies producing PID controllers. The first one is *time-domain method*; according to it, the PID coefficients are calculated using the effective time delay and the effective time constant of the step response of the industrial plant. The *frequency-domain method* uses the critical gain K_c and the period of critical oscillations T_c to calculate the PID coefficients according to the relations $\Theta_{\text{PID}} = (P, T_i, T_d) = (\alpha_1 K_c, \alpha_2 T_c, \alpha_3 T_c)$, where the weights of critical parameters are $(\alpha_1, \alpha_2, \alpha_3) = (0.6, 0.5, 0.125)$.

2.4.1.2. Tuning rules based on ultimate parameters of the industrial process

Due to its simplicity, the Ziegler-Nichols frequency-domain methods are still used in industrial autotuners in the original version, although they have undergone various modifications during the last 70 years of its existence. Due to the technological development after the industrial revolution and major electrification, PID tuning for stability was no more sufficient because a fast setpoint attainment could bring about important savings of time and money and

accelerate the entire production process. More and more demanding requirements on control performance were formulated, and an intense demand for effective tuning methods guaranteeing required performance has arisen.

As a rule, application of Ziegler-Nichols methods usually leads to oscillatory closed-loop responses; hence, many scientists have become interested in their possible improvement. Forty-two modifications of the Ziegler-Nichols frequency method were developed in the period from 1967 to 2010. They differ from the classical algorithm in using various other combinations of the weights ($\alpha_1, \alpha_2, \alpha_3$). An overview of selected model-free methods is given in **Table 2**.

Tuning rules No. 1–3 are the well-known Ziegler-Nichols frequency-domain method which objective is a fast rejection of the disturbance $d(t)$ and $\delta_{DR} = 1:4$. In the complex plane interpretation (**Figure 6**), the method corresponds to shifting the critical point $C = [-1/K_c + j0]$, into the points $C_P = [-0.5 + j0]$, $C_{PI} = [-0.45 + j0.0896]$ and $C_{PID} = [-0.6 - j0.28]$ using respectively P, PI and PID controllers tuned according to **Table 2**. Put simply, the open-loop Nyquist plot is shaped into a sufficient distance from the limit of instability specified by the point $(-1, j0)$.

No.	Design method, year	Controller	K	T_i	T_d	Performance
1.	Ziegler and Nichols, 1942 [48]	P	$0.5K_c$	—	—	Quarter decay ratio
2.	Ziegler and Nichols, 1942 [48]	PI	$0.45K_c$	$0.8T_c$	—	Quarter decay ratio
3.	Ziegler and Nichols, 1942 [48]	PID	$0.6K_c$	$0.5T_c$	$0.125T_c$	Quarter decay ratio
4.	Pettit and Carr, 1987 [27]	PID	K_c	$0.5T_c$	$0.125T_c$	Underdamped
5.	Pettit and Carr, 1987 [27]	PID	$0.67K_c$	T_c	$0.167T_c$	Critically damped
6.	Pettit and Carr, 1987 [27]	PID	$0.5K_c$	$1.5T_c$	$0.167T_c$	Overdamped
7.	Chau, 2002 [16]	PID	$0.33K_c$	$0.5T_c$	$0.333T_c$	Small overshoot
8.	Chau, 2002 [16]	PID	$0.2K_c$	$0.55T_c$	$0.333T_c$	No overshoot
9.	Bucz, 2011 [6]	PID	$0.54K_c$	$0.79T_c$	$0.199T_c$	Overshoot $\eta_{max} \leq 20\%$
10.	Bucz, 2011 [6]	PID	$0.28K_c$	$1.44T_c$	$0.359T_c$	Settling time $t_s \leq 13/\omega_c$

Table 2. Model-free PID controller tuning rules based on critical plant parameters.




Figure 6. Moving the critical point $C = [-1/K_c + j0]$ of the plant using P, PI and PID controllers designed by Ziegler-Nichols frequency-domain method for critical frequency ω_c of the plant.

Related methods (No. 4–10) use various weighting of critical parameters thus allowing to vary the closed-loop performance requirements (see the last column in **Table 2**). All presented methods (No. 1–10) are applicable for various plant types, easy-to-use and time efficient.

2.4.1.3. Specification of critical parameters of the plant using relay experiment

In autotuners of industrial controllers, a relay test [29] using an ideal relay (IR) or a hysteresis relay (HR) is used to quickly determine the plant critical parameters K_c and T_c . In the manual mode, after setting the nominal setpoint $w(t)$ and switching the SW to position “3”, a stable limit cycle around the nominal working point $y(t)$ arises in the control loop in **Figure 1**. As a result of switching between the $-M$, $+M$ relay levels, the controlled system $G(s)$ is excited by a rectangular periodic signal $u(t)$ (**Figure 7a**). The critical frequency ω_c and the critical gain K_c are calculated as follows:

$$\omega_c = \frac{2\pi}{T_c}; \quad K_{c_IR} = \frac{4M}{\pi A_c}; \quad K_{c_HR} = \frac{4(M - 0.5\Delta_{DB})}{\pi A_c}, \quad (10)$$

where the period T_c and the amplitude A_c of critical oscillations are read off from $y(t)$ of the recorded limit cycle (**Figure 7b**); Δ_{DB} is the width of the hysteresis plot, the relay amplitude M is chosen as (3÷10)% of the control $u(t)$ limits. A typical limit cycle is depicted in **Figure 7b**. A hysteresis relay is used if $y(t)$ corrupted by a noise $n(t)$ [47].

The advantage of these methods is their applicability for different types of systems, simplicity and the short time needed for the controller design of the—approx. $(3\div 4)T_c$.

2.4.2. Model-based PID controller tuning with guaranteed performance

In these methods, the identified characteristics of the unknown system are used to create its typical model, and the controller design algorithm is derived for this particular model. Formulas for calculation of the controller coefficients include process model parameters that are function of the identified process data. Each method works perfectly for the system whose model has been used in the design algorithm. However, if the system is approximated differently, the achieved performance may be impaired or even insufficient. The advantage is that control objectives can be clearly defined and expressed using analytical relationships (e.g., it is possible to derive the relationship for maximum overshoot of the step response). A small flexibility due to the “tailor-made” design for one type of model limits the widespread application of these methods in autotuners of industrial controllers.

PID tuning algorithms of indirect tuning methods have two more steps compared with direct methods, as shown in the flow chart in **Figure 8**. When choosing the procedure for creating a




Figure 7. Determination of critical parameters K_c and T_c of the controlled plant from the limit cycle.




Figure 8. Flow chart of the indirect engineering method for PID tuning.

typical model ③.①, it is important how the implicit information about the controlled system is considered (if we deal with a driving system, a thermal process, a mechanical or pneumatic system, etc.). If the typical model for the given controlled system has already been selected, the model parameters are calculated in step ③.② and subsequently used in calculation of the PID coefficients.

2.4.2.1. Specification of FOLPDT, IPDT and FOLIPDT plant model parameters

The static and dynamic properties of most technological processes can be expressed by one of the FOLPDT, IPDT, FOLIPDT, or SOSPDT models. Model parameters are identified from the recorded step response of the controlled system (Figure 9) and are further used in calculation of PID controller coefficients. According to Figure 1, step response of the controlled process is obtained by switching SW into position “2” and performing step change in $u(t)$.

Transfer functions of the model are found from the step response parameters according to Figure 9.

$$G_{FOLPDT}(s) = \frac{K_1 e^{-D_1 s}}{T_1 s + 1}; \quad G_{IPDT}(s) = \frac{K_2 e^{-D_2 s}}{s}; \quad G_{FOLIPDT}(s) = \frac{K_3 e^{-D_3 s}}{s(T_3 s + 1)}. \quad (11)$$




Figure 9. Typical step responses of (a) FOLPDT; (b) IPDT and (c) FOLIPDT models.

No.	Design method, year, control purpose	Controller	K	T _i	T _d	Performance
11.	Ziegler and Nichols, 1942 [48]	P	1/ϑ ₁	—	—	Quarter decay ratio
12.	Ziegler and Nichols, 1942 [48]	PI	0.9/ϑ ₁	3D ₁	—	
13.	Ziegler and Nichols, 1942 [48]	PID	1.2/ϑ ₁	2D ₁	0.5D ₁	
14.	Chien et al., 1952, regulator tuning [18]	PI	0.6/κ ₁	4D ₁	—	η _{max} = 0%, D ₁ /T ₁ ∈ (0.1;1)
15.	Chien et al., 1952, regulator tuning [18]	PID	0.95/ϑ ₁	2.38D ₁	0.42D ₁	
16.	Chien et al., 1952, regulator tuning [18]	PI	0.77/ϑ ₁	2.33D ₁	—	η _{max} = 20%, D ₁ /T ₁ ∈ (0.1;1)
17.	Chien et al., 1952, regulator tuning [18]	PID	1.2/ϑ ₁	2D ₁	0.42D ₁	
18.	Chien et al., 1952, servo tuning [18]	PI	0.35/ϑ ₁	1.17D ₁	—	η _{max} = 0%, D ₁ /T ₁ ∈ (0.1;1)
19.	Chien et al., 1952, servo tuning [18]	PID	0.6/ϑ ₁	D ₁	0.5D ₁	
20.	Chien et al., 1952, servo tuning [18]	PI	0.6/ϑ ₁	D ₁	—	η _{max} = 20%, D ₁ /T ₁ ∈ (0.1;1)
21.	Chien et al., 1952, servo tuning [18]	PID	0.95/ϑ ₁	1.36D ₁	0.47D ₁	
22.	ControlSoft Inc., 2005 [23]	PID	2/K ₁	T ₁ + D ₁	max(D ₁ /3; T ₁ /6)	Slow loop
23.	ControlSoft Inc., 2005 [23]	PID	2/K ₁	T ₁ + D ₁	min(D ₁ /3; T ₁ /6)	Fast loop

Table 3. PID tuning rules based on FOPDT model, ϑ₁ = K₁D₁/T₁ is the normalized process gain.

2.4.2.2. PID controller tuning formulas for FOLPDT models

The FOPDT model (11a) is used to approximate dynamics of chemical processes, thermal plants, production processes, and so on. To calculate the P, PI and PID controller, coefficients based on the parameters of the FOLPDT model of the controlled system, the tuning formulas in **Table 3** can be used.

2.4.2.3. PID controller tuning formulas for IPDT and FOLIPDT models

While dynamics of slow technological processes (polymer production, heat exchange, etc.) can be approximated by an IPDT model (11b), electromechanical subsystem of rotating machines and servo drive objects are typical examples for using a FOLIPDT model [42] (11c) (**Table 4**).

The gain K in the rule No. 27 is variable with respect to the normalized time delay v₃ = D₃/T₃ of the FOLIPDT model; for the corresponding pairs holds: (v₃; x₃) = {(0.02;5), (0.053;4), (0.11;3), (0.25;2.2); (0.43;1.7); (1;1.3); (4;1.1)}.

No.	Design method, year, model	Controller	K	T _i	T _d	Performance
24.	Haalman, 1965, IPDT model [12]	P	0.66/(K ₂ D ₂)	—	—	M _s = 1.9
25.	Ziegler and Nichols, 1942, IPDT model [48]	PI	0.9/(K ₂ D ₂)	3.33D ₂	—	Quarter decay ratio
26.	Ford, 1953, IPDT model [10]	PID	1.48/(K ₂ D ₂)	2D ₂	0.37D ₂	Decay ratio 1:2.7
27.	Coon, 1956, FOLIPDT model [8]	P	$\frac{x_3}{K_3(T_3+D_3)}$	—	—	Quarter decay ratio
28.	Haalman, 1965, FOLIPDT model [12]	PD	0.66/(K ₃ D ₃)	—	T ₃	M _s = 1.9

Table 4. PID tuning rules based on IPDT and FOLIPDT model parameters.

2.4.2.4. PID controller tuning formulas for SOSPDT plant models

Flexible systems in wood processing industry, automotive industry, robotics, shocks and vibrations damping are often modeled by SOSPDT models with transfer functions

$$G_{SOSPDT}(s) = \frac{K_4 e^{-D_4 s}}{(T_{4s} + 1)(T_{5s} + 1)}; \quad G_{SOSPDT}(s) = \frac{K_6 e^{-D_6 s}}{T_6^2 s^2 + 2\xi_6 T_6 s + 1}, \quad (12)$$

where for SOSPDT model (12b) the relative damping $\xi_6 \in (0;1)$ indicates oscillatory step response.

If $\xi_4 > 1$, SOSPDT model (12a) is used; its parameters are found from the nonoscillatory step response in **Figure 10a** using the following relations

$$T_{4.5} = \frac{1}{2} \left(C_2 \pm \sqrt{C_2^2 - 4C_1^2} \right); \quad D_4 = \frac{t_{0.33}}{0.516} - \frac{t_{0.7}}{1.067}; \quad C_1 = \frac{(t_{0.33} - t_{0.7})}{1.529}; \quad C_2 = \frac{S}{y(\infty)}, \quad (13)$$

where $S = K_4(T_4 + T_5 + D_4)$ is the area above the step response of the process output $y(t)$, and $y(\infty)$ is its steady-state value.

Parameters of the SOSPDT model (12b) can be found from evaluation of 2–4 periods of step response oscillations (**Figure 10b**) using following rules [39]

$$\xi_6 = \frac{-\ln \frac{a_{i+1}}{a_i}}{\sqrt{\pi^2 + \ln^2 \frac{a_{i+1}}{a_i}}}; \quad T_6 = \frac{\sqrt{1 - \xi_6^2}}{\pi N} (t_{N+1} - t_1); \quad D_6 = \frac{1}{N} \left[\sum_{i=1}^N t_i - \frac{N+1}{2} (t_{N+1} - t_1) \right]. \quad (14)$$

Quality of identification improves with increasing number N of read-off amplitudes. If $N > 2$ several values ξ_6 , T_6 and D_6 are obtained, and their average is taken for further calculations. **Table 5** summarizes useful tuning formulas for both oscillatory and nonoscillatory systems with SOSPDT model properties.

Using tuning methods shown in **Tables 2–5**, achieved performance is a priori given by the particular method (e.g., quarter decay ratio when using Ziegler-Nichols methods No. 11–13 in **Table 3**) or guarantees performance however not specified by the designer (e.g., in Chen




Figure 10. Step response of (a) nonoscillatory, (b) oscillatory SOSPDT model.

No.	Method, year	Controller	K	T _i	T _d	Performance for
29.	Suyama, 1992 [30]	PID	$\frac{T_4+T_5}{2K_1D_4}$	T ₄ + T ₅	$\frac{T_4T_5}{T_4+T_5}$	Closed-loop step response overshoot η _{max} = 10%
30.	Vítečková, (1999) [40], Vítečková et al. (2000) [41]	PID	$x_4 \frac{T_4+T_5}{K_1D_4}$	T ₄ + T ₅	$\frac{T_4T_5}{T_4+T_5}$	Overdamped plants; T ₅ > T ₄ η _{max} = 0%: x ₄ = 0.368; η _{max} = 30%: x ₄ = 0.801
31.	Vítečková, (1999) [40], Vítečková et al. (2000) [41]	PID	$\frac{x_6\xi_6T_6}{K_6D_6}$	2ξ ₆ T ₆	$\frac{T_6}{2\xi_6}$	Underdamped plants (0.5 < ξ ₆ ≤ 1) η _{max} = 0%: x ₆ = 0.736; η _{max} = 30%: x ₆ = 1.602
32.	Wang and Shao (1999) [43]	PID	$\frac{x_6\xi_6T_6}{K_6D_6}$	2ξ ₆ T ₆	$\frac{T_6}{2\xi_{6b}}$	[G _M = 2, φ _M = 45°]: x ₆ = 1.571 [G _M = 5, φ _M = 72°]: x ₆ = 0.628
33.	Chen et al., 1999 [17]	PID	$\frac{x_6\xi_6T_6}{K_6D_6}$	2ξ ₆ T ₆	$\frac{D_6}{2\xi_6}$	[G _M ; φ _M ; M _s] = [3.14; 61.4°; 1]: x ₆ = 1.0 [G _M ; φ _M ; M _s] = [1.96; 44.1°; 1.5]: x ₆ = 1.6

Table 5. Tuning rules based on SOSPTD model parameters.

No.	Method, year	K	T _i	T _d	T _f	Performance
34.	Visioli, 2001, Regulator tuning [36]	1.37v ₁ /K ₁	2.42T ₁ v ₁ ^{1.18}	0.60T ₁	—	Minimum ISE
35.	Visioli, 2001, Regulator tuning [36]	1.37v ₁ /K ₁	4.12T ₁ v ₁ ^{0.90}	0.55T ₁	—	Minimum ISTE
36.	Visioli, 2001, Regulator tuning [36]	1.70v ₁ /K ₁	4.52T ₁ v ₁ ^{1.13}	0.50T ₁	—	Minimum IST ² E
37.	Chandrashekar et al., 2002 [15]	10.3662/K ₁	0.3874T ₁	0.0435T ₁	0.0134T ₁	t _s = 0.1 T ₁ ; v ₁ = 0.1
38.	Chandrashekar et al., 2002 [15]	2.0217/K ₁	4.65T ₁	0.2366T ₁	0.0696T ₁	t _s = 0.8 T ₁ ; v ₁ = 0.5

Table 6. Tuning rules for unstable FOPDT model.

method No. 33 in Table 5 gain margin G_M = 1.96, phase margin φ_M = 44.1° and maximum peak M_s = 1.5 of the sensitivity to disturbance d(t)).

2.4.2.5. PID controller tuning formulas for unstable FOLPDT models

Minimization of performance indices can be applied also for unstable FOLPDT models

$$G_{FOLPDT_US}(s) = \frac{K_1 e^{-D_1 s}}{T_1 s - 1} \tag{15}$$

leading to simple tuning rules for PID controller (1a) (No. 34–38 in Table 6). Tuning rules No. 37 and 38 for PID controller (1c) show that settling time t_s increases with growing normalized time delay v₁ = D₁/T₁ of the FOLPDT model (15).

2.5. PID controller design for specified performance

The main benefit of these methods consists of that all tuning rules are based on a single tuning parameter that enables to systematically affect the closed-loop performance by step response shaping [32].

No.	Design method, year, model	K	T _i	T _d
39.	Hang and Åström, 1988, Nonmodel [13]	$K_c \sin \varphi_M$	$\frac{T_c(1 - \cos \varphi_M)}{\pi \sin \varphi_M}$	$\frac{T_c(1 - \cos \varphi_M)}{4\pi \sin \varphi_M}$
40.	Rotach, 1994, Nonmodel [28]	$\frac{M_t G(j\omega_{M_t}) }{\sqrt{M_t^2 - 1}}$	$\frac{-2}{\omega_{M_t}^2 \left(\frac{d(\arg G(j\omega_{M_t}))}{d\omega_{M_t}} \right)}$	$-\frac{1}{2} \frac{d(\arg G(j\omega_{M_t}))}{d\omega_{M_t}}$
41.	Wojsznis et al., 1999, FOPDT [45]	$\frac{K_c \cos \varphi_M}{G_M}$	$\frac{T_c}{\pi} (t_g \varphi_M + \sqrt{1 + t_g^2 \varphi_M^2})$	$\frac{T_c}{4\pi} (t_g \varphi_M + \sqrt{1 + t_g^2 \varphi_M^2})$
42.	Morari and Zafiriou, 1989, FOPDT [22]	$\frac{T_i + 0.5D_1}{K_1(\lambda + D_1)}$	$T_1 + \frac{1}{2}D_1$	$\frac{T_1 D_1}{2T_1 + D_1}$
43.	Chen and Seborg, 2002, FOPDT [17]	$\frac{T_1^2 + T_1 D_1 - (\lambda - T_1)^2}{(\lambda + L)^2}$	$\frac{T_1^2 + T_1 D_1 - (\lambda - T_1)^2}{T_1 + L_1}$	-

Table 7. PID design for specified performance based on tuning parameters φ_M , G_M , M_t and λ .

2.5.1. PID controller tuning formulas with performance specification

Table 7 shows open formulas for PID controller design; their tuning is carried out with respect to closed-loop performance specification.

Rules No. 39–43 consider tuning of ideal PID controller (1a). To apply the Rotach method [29], knowledge of the plant magnitude $|G(j\omega)|$ is supposed as well as of the roll-off of the phase plot $\arg G(\omega)$ at $\omega = \omega_{M_t}$, where the maximum peak M_t of the complementary sensitivity is required. Method No. 42 is based on the so-called λ -tuning, where the resulting closed-loop is expressed as a 1st order system with time constant λ ; this rule considers real PID controller (1b) with filtering constant in the derivative part $T_f = 0.5\lambda D_1 / (1 + D_1)$, where λ is to be chosen so as to meet following conditions: $\lambda > 0.25D_1$; $\lambda > 0.25T_1$ [22]. The λ -tuning technique is used also in the rule No. 43 to design interaction PI controller.

2.5.2. Closed-loop performance evaluation under PID controller tuning

Phase margin φ_M is the most widespread performance measure in PID controller design. Maximum overshoot η_{\max} and settling time t_s of the closed-loop step response are related with φ_M according to Reinisch relations

$$\eta_{\max} = \begin{cases} -0.91\varphi_M + 64.55 & \text{for } \varphi_M \in \langle 38^\circ, 71^\circ \rangle \\ -1.53\varphi_M + 88.46 & \text{for } \varphi_M \in \langle 12^\circ, 38^\circ \rangle \end{cases}; \quad \eta_{\max} = 100e^{-2\pi b^2 M_t}; \quad t_s \in \left(\frac{\pi}{\omega_a^*}, \frac{4\pi}{\omega_a^*} \right) \quad (16)$$

valid for second-order closed-loop with relative damping $\omega_a^* \in (0.25; 0.65)$ where ω_a^* is the gain crossover frequency [14]. Relations

$$\eta_{\max} \leq 100 \frac{1.18M_t - |T(0)|}{|T(0)|} [\%]; \quad t_s \approx \frac{3}{\omega_a^*} \text{ for } M_t \in (1.3, 1.5) \quad (17)$$

are general for any order of the closed-loop $T(s)$; if the controller has the integral part then $|T(0)| = |T(\omega = 0)| = 1$ [14].

The engineering practice is persistently demanding for PID controller design methods that simultaneously guarantee several performance criteria [24], especially the maximum

overshoot η_{\max} and the settling time t_s . However, we ask the question: how to suitably transform the abovementioned engineering requirements into frequency-domain specifications applicable for PID controller coefficients tuning? The response can be found in Section 3 in which a novel original PID controller design method is presented.

3. PID controller design for specified performance based on harmonic excitation

The proposed original method [6] enables to guarantee required closed-loop performance for a whole family of plants specified by the uncertainty description. The core of it is the recently developed PID controller design method based on external harmonic excitation [7]—a two-step PID tuning method for performance specified in terms of maximum overshoot η_{\max} and settling time t_s .

In the first step, the plant is identified using external harmonic excitation signal (a sinusoid) with the frequency ω_n . In the second step, two developed PID controller design approaches can be applied:

1. the approach based on guaranteed phase margin ϕ_M suitable for nonintegrating systems with/without time delay and for integrating systems as well;
2. the approach based on guaranteed gain margin G_M suitable for nonintegrating systems with unstable zero.

For the ϕ_M -based approach, the specified performance is achieved by means of developed quadratic dependences $\eta_{\max} = f(\phi_M, \omega_n)$ and $t_s = f(\phi_M, \omega_n)$ parameterized by ω_n ; the corresponding plots are called B-parabolas. For the G_M -based approach similar quadratic dependences for both the maximum overshoot $\eta_{\max} = f(G_M, \omega_n)$ and the settling time $t_s = f(G_M, \omega_n)$ were constructed. These approaches enable to achieve fulfillment of the following performance measures (ω_c is the plant ultimate frequency):

- for plants without integration behavior: $\eta_{\max} \in \langle 0\%, 90\% \rangle$ and $t_s \in \langle 6.5/\omega_c, 45/\omega_c \rangle$,
- for plants with integration behavior: $\eta_{\max} \in \langle 9.5\%, 90\% \rangle$ and $t_s \in \langle 11.5/\omega_c, 45/\omega_c \rangle$,
- for plants with unstable zero: $\eta_{\max} \in \langle 0\%, 90\% \rangle$ and $t_s \in \langle 8.5/\omega_c, 45/\omega_c \rangle$.

A setup for the proposed harmonic excitation based method [7] is in **Figure 11**, where $G(s)$ is a transfer function of the controlled plant with unknown mathematical model, $G_R(s)$ is a PID controller transfer function, and SW is a switch.

3.1. Process identification using external harmonic excitation

A sinusoidal excitation signal $u(t) = U_n \sin(\omega_n t)$ is injected into the plant $G(s)$ when the switch is in the position SW = 4. The plant output $y(t)$ is sinusoidal as well with the same frequency ω_n , magnitude Y_n and a phase lag φ , that is $y(t) = Y_n \sin(\omega_n t + \varphi)$, where $\varphi = \arg G(\omega_n)$ (**Figure 12**).




Figure 11. A setup for implementation of the external harmonic excitation based method.




Figure 12. Time responses of (a) $u(t)$; (b) $y(t)$, and (c) location of $G(j\omega_n)$ in the complex plane.

After obtaining Y_n and φ from the recorded time responses $u(t)$ and $y(t)$, one point of the (unknown) plant frequency characteristics related with the excitation frequency ω_n can be plotted in the complex plane (Figure 12)

$$G(j\omega_n) = |G(j\omega_n)|e^{j\arg G(j\omega_n)} = \frac{Y_n(\omega_n)}{U_n(\omega_n)}e^{j\varphi(\omega_n)}. \quad (18)$$

It is recommended to choose $U_n = (3\div 7)\%u_{\max}$ [7]. Identified plant parameters are described by the triple $\{\omega_n, Y_n/U_n, \varphi\}$. Note that if SW = 4, the identification is performed in open-loop, hence this approach is applicable for stable plants only.

3.2. PID controller tuning rules based on harmonic excitation

Based on identified plant parameters, PID controller can be tuned using the phase margin and/or gain margin approaches. In the control loop in Figure 11, switch SW in "5" and the PID controller in manual mode. To guarantee a specified phase margin ϕ_M at the gain crossover frequency ω_a^* , the closed-loop characteristic equation under a PID controller $1 + L(j\omega) = 1 + G(j\omega)G_R(j\omega) = 0$ can be easily broken down into the magnitude and phase conditions ($\omega_a^* = \omega_n$ and ϕ_M is the required phase margin, $L(j\omega)$ is the loop transfer function)

$$|G(j\omega_n)||G_R(j\omega_n)| = 1, \arg G(\omega_n) + \arg G_R(\omega_n) = -180^\circ + \varphi_M. \quad (19)$$

To guarantee a specified gain margin G_M at the phase crossover frequency ω_p^* , the closed-loop characteristic equation can be expressed by the magnitude and phase conditions [6] as follows ($\omega_p^* = \omega_n$)

$$|G(j\omega_n)||G_R(j\omega_n)| = 1/G_M, \arg G(\omega_n) + \arg G_R(\omega_n) = -180^\circ. \tag{20}$$

Graphical interpretation of (19), (20) is shown in **Figure 13**. Let us denote $\varphi = \arg G(\omega_n)$, $\Theta = \arg G_R(\omega_n)$, and consider the ideal PID controller (1a), where K is proportional gain, and T_i, T_d are the integral and the derivative time constants, respectively. Substituting for $s = j\omega_n$ into (1a) we obtain

$$G_R(j\omega_n) = K + jK \left[T_d \omega_n - \frac{1}{T_i \omega_n} \right]. \tag{21}$$

Comparison of (21) with its polar form

$$G_R(j\omega_n) = |G_R(j\omega_n)|e^{j\Theta} = |G_R(j\omega_n)|[\cos \Theta + j \sin \Theta] \tag{22}$$

yields a complex Eq. (23) for phase margin approach and (24) for gain margin approach

$$K + jK \left[T_d \omega_n - \frac{1}{T_i \omega_n} \right] = \frac{\cos \Theta}{|G(j\omega_n)|} + j \frac{\sin \Theta}{|G(j\omega_n)|}, \tag{23}$$

$$K + jK \left[T_d \omega_n - \frac{1}{T_i \omega_n} \right] = \frac{\cos \Theta}{G_M |G(j\omega_n)|} + j \frac{\sin \Theta}{G_M |G(j\omega_n)|}. \tag{24}$$

Finally, PID controller parameters are obtained from (23), (24) using the substitution $|G_R(j\omega_n)| = 1/|G(j\omega_n)|$ for the phase margin approach and $|G_R(j\omega_n)| = 1/[G_M |G(j\omega_n)|]$ for the gain




Figure 13. Graphical interpretation of (a) ϕ_M, ω_a^* and shifting G into L_A at $\omega_a^* = \omega_n$; (b) G_M, ω_f^* and shifting G into L_F at $\omega_f^* = \omega_n$.

margin approach resulting from (24). The complex equations (23), (24) are solved as a set of two real equations (25) for the phase margin or (26) for the gain margin approaches, respectively

$$K = \frac{\cos \Theta}{|G(j\omega_n)|}, K \left[T_d \omega_n - \frac{1}{\beta T_d \omega_n} \right] = \frac{\sin \Theta}{|G(j\omega_n)|}, \tag{25}$$

$$K = \frac{\cos \Theta}{G_M |G(j\omega_n)|}, K \left[T_d \omega_n - \frac{1}{\beta T_d \omega_n} \right] = \frac{\sin \Theta}{G_M |G(j\omega_n)|}, \tag{26}$$

where (25a, 26a) represent general rules for calculating the controller gain K. After substituting (25a), (26a) and the ratio $\beta = T_i/T_d$ into (25b), (26b), after some manipulations we obtain a quadratic equation in T_d for both approaches

$$T_d^2 \omega_n^2 \beta - T_d \omega_n \beta t g \Theta - 1 = 0. \tag{27}$$

Expression for calculating T_d is the positive solution of (27)

$$T_d = \frac{t g \Theta}{2 \omega_n} + \frac{1}{\omega_n} \sqrt{\frac{t g^2 \Theta}{4} + \frac{1}{\beta}} \tag{28}$$

Hence, the PID controller parameters are calculated using the expressions (25a), (26a), $T_i = \beta T_d$ and (28); Θ is obtained from (19b) using (29) for the phase margin approach and (20b) for the gain margin approach

$$\Theta = -180^\circ + \phi_M - \arg G(\omega_n) = -180^\circ + \phi_M - \varphi, \tag{29}$$

$$\Theta = -180^\circ - \arg G(\omega_n) = -180^\circ - \varphi. \tag{30}$$

Using the PID controller designed for the phase margin ϕ_M , the identified point G of the plant Nyquist plot $G(j\omega)$ with co-ordinates (1) is moved into the point L_A of the open-loop Nyquist plot located on the unit circle M_1 (**Figure 13a**). In this way, the gain crossover L_A of the open-loop $L(j\omega)$ is specified

$$L_A \equiv L(j\omega_n) = [|L(j\omega_n)|, \arg L(\omega_n)] = [1, \phi_M], \tag{31}$$

for which the designed PID controller guarantees the required phase margin ϕ_M ; so for ω_n is $|L(j\omega_n)| = 1$. In case of PID controller design for gain margin G_M , the identified point G of the plant Nyquist plot $G(j\omega)$ with co-ordinates (1) is moved into the open-loop frequency response point L_F lying on the negative real half-axis of the complex plane (**Figure 13b**). In this way, the phase crossover L_F of the open-loop $L(j\omega)$ is specified

$$L_F \equiv L(j\omega_f^* \equiv \omega_n) = [|L(j\omega_n)|, \arg L(\omega_n)] = \left[\frac{1}{G_M}, -180^\circ \right]. \tag{32}$$

Location of the points $G(j\omega_n)$ and $L(j\omega_n)$ in the complex plane is shown in **Figure 13**.

No.	Design method, year	Controller	K	T _i	T _d	Range of Θ
44.	Ext. sinusoidal excitation method, Phase-margin approach 2017, Θ = -180° + φ _M - φ	PI	$\frac{\cos \Theta}{ G(j\omega_n) }$	$\frac{-1}{\omega_n \operatorname{tg} \Theta}$	-	$\left(-\frac{\pi}{2}; 0\right)$
45.	Ext. sinusoidal excitation method, Phase-margin approach 2017, Θ = -180° + φ _M - φ	PD	$\frac{\cos \Theta}{ G(j\omega_n) }$	-	$\frac{1}{\omega_n} \operatorname{tg} \Theta$	$\left(0; \frac{\pi}{2}\right)$
46.	Ext. sinusoidal excitation method, Phase-margin approach 2017, Θ = -180° + φ _M - φ	PID	$\frac{\cos \Theta}{ G(j\omega_n) }$	βT_d	$\frac{\operatorname{tg} \Theta}{2\omega_n} + \frac{1}{\omega_n} \sqrt{\frac{\operatorname{tg}^2 \Theta}{4} + \frac{1}{\beta}}$	$\left(-\frac{\pi}{2}; \frac{\pi}{2}\right)$
47.	Ext. sinusoidal excitation method, Gain-margin approach 2017, Θ = -180° - φ	PI	$\frac{\cos \Theta}{G_M G(j\omega_n) }$	$\frac{-1}{\omega_n \operatorname{tg} \Theta}$	-	$\left(-\frac{\pi}{2}; 0\right)$
48.	Ext. sinusoidal excitation method, Gain-margin approach 2017, Θ = -180° - φ	PD	$\frac{\cos \Theta}{G_M G(j\omega_n) }$	-	$\frac{1}{\omega_n} \operatorname{tg} \Theta$	$\left(0; \frac{\pi}{2}\right)$
49.	Ext. sinusoidal excitation method, Gain-margin approach 2017, Θ = -180° - φ	PID	$\frac{\cos \Theta}{G_M G(j\omega_n) }$	βT_d	$\frac{\operatorname{tg} \Theta}{2\omega_n} + \frac{1}{\omega_n} \sqrt{\frac{\operatorname{tg}^2 \Theta}{4} + \frac{1}{\beta}}$	$\left(-\frac{\pi}{2}; \frac{\pi}{2}\right)$

Table 8. PI, PD and PID controller tuning rules using the harmonic excitation method.

PI, PD and PID tuning formulas for both approaches (φ_M and G_M) are summed up in Table 8. The excitation frequency can be adjusted according to the empirical relations [6].

$$\omega_n \in \langle 0.2\omega_c, 0.95\omega_c \rangle; \omega_n \in \langle 0.5\omega_c, 1.25\omega_c \rangle. \tag{33}$$

$\phi_{M\text{-approach}} \qquad G_{M\text{-approach}}$

3.3. Controller structure selection using the “triangle ruler” rule

The argument Θ in the tuning rules in Table 8 indicates the angle to be contributed to the identified phase φ at ω_n by the controller to obtain the resulting open-loop phase (-180° + φ_M) necessary to guarantee the required phase margin φ_M (or the gain margin G_M). Working range of the PID controller argument is given by the union of PI and PD controllers phase ranges

$$\Theta_{PID} \in \Theta_{PI} \cup \Theta_{PD} = (-90^\circ, 0^\circ) \cup (0^\circ, +90^\circ) = (-90^\circ, +90^\circ), \tag{34}$$

which is symmetric with respect to 0° and due to frequency properties of PI, PD and PID controllers also upper- and lower-bounded. The working range (34) can be interpreted using a pretended transparent triangular ruler turned according to Figure 14; its segments to the left and right of the axis of symmetry represent the PD and PI working ranges, respectively.

Figure 14a shows the situation, when the identified point G is situated in the 1st quadrant of the complex plane. In case of phase-margin approach, put this ruler on Figure 14a, the middle of the hypotenuse on the origin of the complex plane and turn it so that its axis of symmetry merges with the ray (0,G). Thus, the ruler determines in the complex plane the cross-hatched area representing the full working range of the PID controller argument. The controller type is chosen depending on the situation of the ray (0,L_A) forming with the negative real half-axis the angle φ_M: situation of the ray (0,L_A) in the left-hand sector suggests a PD controller, and in the




Figure 14. Controller structure selection using the “triangle ruler” rule with respect to the situation of (a) G and L_A ; (b) G and L_F .

right-hand sector the PI controller. **Figure 14a** shows the case, when the phase margin ϕ_M is achievable using both PI or PID controller. According to **Figure 14b**, the identified point G is placed in 2nd quadrant of the complex plane. Applying the gain-margin approach, the ruler is to be put on **Figure 14b** according to the similar setup than in case of phase-margin approach. The controller type is chosen depending on the situation of the ray $(0, L_F)$ lying on the border of the second and third quadrants of the complex plane; in this case, PI or PID controller type has to be chosen.

3.4. Closed-loop performance

This subsection answers the following question: how to transform the practical performance requirements in terms of maximum overshoot η_{max} and settling time t_s into the couple of frequency-domain parameters (ω_n, ϕ_M) needed for identification and PID controller coefficients tuning?

3.4.1. Systems without integrator

Looking for an appropriate transformation $\mathfrak{R}: (\eta_{max}, t_s) \rightarrow (\omega_n, \phi_M)$ we will consider typical phase margins ϕ_M given by the set

$$\{\varphi_{Mj}\} = \{20^\circ, 30^\circ, 40^\circ, 50^\circ, 60^\circ, 70^\circ, 80^\circ, 90^\circ\}, \quad (35)$$

$j = 1 \dots 8$. Let us split (33a) into 5 equidistant sections $\Delta\omega_n = 0.15\omega_\sigma$ and generate the set of excitation frequencies

$$\{\omega_{nk}\} = \{(0.2, 0.35, 0.5, 0.65, 0.8, 0.95)\omega_c\} = \{\sigma_k\omega_c\}, \tag{36}$$

$k = 1 \dots 6$. Its elements divided by the plant critical frequency ω_c determine the set of so-called excitation levels

$$\{\sigma_k\} = \{0.2, 0.35, 0.5, 0.65, 0.8, 0.95\}, \tag{37}$$

$k = 1 \dots 6$. Let us demonstrate the qualitative effect of ω_{nk} and ϕ_{Mj} on closed-loop step response for the plant

$$G_3(s) = \frac{1}{(s + 1)(0.5s + 1)(0.25s + 1)(0.125s + 1)} \tag{38}$$

under PID controllers designed for three phase margins $\phi_M = 40^\circ, 60^\circ, 80^\circ$ on three excitation levels $\sigma_1 = \omega_{n1}/\omega_c = 0.2$; $\sigma_3 = \omega_{n3}/\omega_c = 0.5$ and $\sigma_5 = \omega_{n5}/\omega_c = 0.8$. Related closed-loop step responses are shown in **Figure 15**.

Achieving required t_s and η_{\max} was tested by designing PID controller for a vast set of benchmark examples [2] at excitation frequencies and phase margins expressed by a Cartesian product $\phi_{Mj} \times \omega_{nk}$ of the sets (35) and (36) for $j = 1 \dots 8, k = 1 \dots 6$. Resulting dependences $\eta_{\max} = f(\phi_M, \omega_n)$ and $t_s = f(\phi_M, \omega_n)$ are plotted in **Figure 16** [6].

Considering the frequencies $\omega_a^* = \omega_n$ are equal which results from the assumptions of the sinusoidal excitation method, the settling time can be expressed by the relation

$$t_s = \frac{\gamma\pi}{\omega_n} \tag{39}$$

similar to (16c) [6], where γ is the curve factor of the step response; in the relation (16c) for the 2nd order closed-loop, γ is from the interval (1;4) and depends on the relative damping [14]. In case of the proposed sinusoid excitation based method γ varies over a considerably broader interval (0.5;16) found empirically and depends strongly on ϕ_M , that is $\gamma = f(\phi_M)$ at the given excitation frequency ω_n . To examine closed-loop settling times for plants with different dynamics, it is advantageous to define the relative settling time [7]




Figure 15. Closed-loop step responses of $G_3(s)$ for various ϕ_M and ω_n .

$$\tau_s = t_s \omega_c. \tag{40}$$

Substituting for $\omega_n = \sigma \omega_c$ into (39) and (40), we obtain a relation for the relative settling time

$$\tau_s = \frac{\pi}{\sigma} \gamma, \tag{41}$$

where t_s is related to the critical frequency ω_c . Due to introducing ω_c the right-hand side in (41) is constant for the given plant and independent of ω_n . The dependency (41) obtained empirically for different excitation frequencies ω_{nk} is depicted in **Figure 16b**; it is evident that at every excitation level σ_k with increasing phase margin ϕ_M the relative settling time τ_s first decreases and after achieving its minimum τ_{s_min} it increases again. The empirical dependences in **Figure 16** have been approximated by quadratic regression curves, thus they are called B-parabolas [7].

3.4.1.1. Discussion

When choosing $\phi_M = 40^\circ$ on the B-parabola corresponding to the excitation level $\sigma_5 = \omega_{n5}/\omega_c = 0.8$ (further denoted as $B_{0.8}$ parabola), maximum overshoot $\eta_{max} = 40\%$ and relative settling time $\tau_s \approx 10$ are expected (see **Figure 16**). Point **1** corresponding to these parameters and is located on the left (falling) portion of $B_{0.8}$ yielding oscillatory step response (see response **1** in **Figure 15c**). If the phase margin to $\phi_M = 60^\circ$ increases, the relative settling time decreases into the point **2** on the right (rising) portion of the $B_{0.8}$ parabola; the corresponding step response **2** in **Figure 15c** is weakly aperiodic. For the phase margin $\phi_M = 80^\circ$, the $B_{0.8}$ parabola indicates a zero maximum overshoot, the relative settling time $\tau_s = 20$ corresponds to the position **3** on the $B_{0.8}$ parabola with aperiodic step response **3** (**Figure 15c**). If the maximum overshoot $\eta_{max} = 20\%$ is acceptable, then $\phi_M = 53^\circ$ yields the least possible relative settling time $\tau_s = 6.5$ on the given level $\sigma_5 = 0.8$ ("at the bottom" of $B_{0.8}$).




Figure 16. Dependences: (a) $\eta_{max} = f(\phi_M, \omega_n)$; (b) $\tau_s = \omega_c t_s = f(\phi_M, \omega_n)$ for $\phi_{Mj} \times \omega_{nk}, j = 1 \dots 8, k = 1 \dots 6$ (relative settling time $\tau_s = t_s \omega_c$).

3.4.1.2. Example 1

Using the sinusoid excitation method, design ideal PID controllers (1a) for an operating amplifier modeled by the transfer function $G_A(s)$

$$G_A(s) = \frac{1}{(T_{As} + 1)^3} = \frac{1}{(0,01s + 1)^3}. \tag{42}$$

The control objective is to guarantee maximum overshoots $\eta_{\max1} = 30\%$, $\eta_{\max2} = 5\%$ and a maximum relative settling time $\tau_s = 12$ in both cases.

3.4.1.3. Solution

1. Critical frequency of the plant identified by the Rotach test is $\omega_c = 173.216[\text{rad/s}]$ (the process is “fast”). The prescribed settling time is $t_s = \tau_s/\omega_c = 12/173.216[\text{s}] = 69.3[\text{ms}]$.
2. For the expected performance $(\eta_{\max1};\tau_s) = (30\%;12)$ (Design No. 1) a satisfactory choice is $(\phi_{M1};\omega_{n1}) = (50^\circ;0.5\omega_c)$ resulting from the $B_{0,5}$ parabola in **Figure 16**. The performance in terms of $(\eta_{\max2};\tau_s) = (5\%;12)$ (Design No. 2) can be achieved by choosing $(\phi_{M2};\omega_{n2}) = (70^\circ;0.8\omega_c)$ resulting from the $B_{0,8}$ parabola in **Figure 16**.
3. Identified points for the first and second designs are $G_A(j0.5\omega_c) = 0.43e^{-j120^\circ}$ and $G_A(j0.8\omega_c) = 0.19e^{-j165^\circ}$, respectively. According to **Figure 17a**, both points are located in the quadrant II of the complex plane, on the Nyquist plot $G_A(j\omega)$ (continuous curve) which verifies the identification.




Figure 17. (a) Open-loop Nyquist plots; (b) closed-loop step responses of the operational amplifier, required performance $\eta_{\max1} = 30\%$, $\eta_{\max2} = 5\%$ and $\tau_s = 12$.

4. Using the PID controller designed for $(\phi_{M1}; \omega_{n1}) = (50^\circ; 0.5\omega_c)$, the point $G_A(j0.5\omega_c)$ is moved into the gain crossover $L_{A1}(j0.5\omega_c) = 1e^{-j130^\circ}$ on the unit circle M_1 , which verifies achieving the phase margin $\phi_{M1} = 180^\circ - 130^\circ = 50^\circ$ (dashed Nyquist plot). The point $G_A(j0.8\omega_c)$ has been moved by the PID controller designed for $(\phi_{M2}; \omega_{n2}) = (80^\circ; 0.8\omega_c)$ into $L_{A2}(j0.8\omega_c) = 1e^{-j110^\circ}$ yielding a phase margin $\phi_{M2} = 180^\circ - 110^\circ = 70^\circ$ (dotted Nyquist plot).
5. Achieved performance read-off from the closed-loop step response in **Figure 17b** (dashed line) is $\eta_{\max1}^* = 29.7\%$, $t_{s1}^* = 58.4[\text{ms}]$. Performance in terms of $\eta_{\max2}^* = 4.89\%$, $t_{s2}^* = 60.5 [\text{ms}]$ identified from the closed-loop step response in **Figure 17b** (dashed line) complies with the required performance.

3.4.2. Systems with time delay

The sinusoid excitation method is applicable also for plants with time delay commonly considered as difficult-to-control systems [1]. It is a well-known fact that at each frequency $\omega_n \in (0, \infty)$ the time delay D turns the phase by $\omega_n D$ with respect to the delay-free system [44]. For time-delayed systems, the phase condition (29) is extended by an additional phase $\varphi_D = -\omega_n D$

$$(\varphi' + \varphi) + \Theta = -180^\circ + \phi_{M'} \tag{43}$$

where φ' is the phase of the delay-free system and

$$\varphi = \varphi' + \varphi_D \tag{44}$$

is the identified phase of the plant including the time delay.

The added phase $\varphi_D = -\omega_n D$ is associated with the required phase margin ϕ_M according to

$$\varphi' + \Theta = -180^\circ + (\phi_M + \omega_n D). \tag{45}$$

The only modification in using the PID tuning rules in **Table 9** is that an increased required phase margin is to be specified.

Model	η_{\max}, τ_s	ω_c [rad/s]	t_s [s]	B-par.	ϕ_M/G_M	ω_n/ω_c	$G(j\omega_n)$	$G_R(j\omega_n)$	η_{\max}^*	t_s^* [s]
$G_A(s)$	30%,12	173.2	0.069	Figure 16	50°	0.5	$0.43e^{-j120^\circ}$	$2.31e^{-j10^\circ}$	29.7%	0.058
$G_A(s)$	5%,12	173.2	0.069	Figure 16	70°	0.8	$0.19e^{-j165^\circ}$	$5.20e^{j55^\circ}$	4.89%	0.061
$G_B(s)$	30%,12	0.352	34.1	Figure 16	$55 + 45.9^\circ$	0.35	$1.03e^{-j23^\circ}$	$0.97e^{-j56^\circ}$	18.6%	24.78
$G_B(s)$	5%,12	0.352	34.1	Figure 16	$70 + 26.2^\circ$	0.2	$1.09e^{-j13^\circ}$	$0.92e^{-j71^\circ}$	0.15%	28.69
$G_C(s)$	30%,20	0.241	83.1	Figure 21	$53 + 10.1^\circ$	0.35	$12.7e^{-j122^\circ}$	$0.08e^{j5.8^\circ}$	29.6%	81.73
$G_C(s)$	20%,20	0.241	83.1	Figure 21	$62 + 14.5^\circ$	0.5	$8.10e^{-j129^\circ}$	$0.12e^{-j28^\circ}$	19.7%	82.44
$G_D(s)$	30%,12	0.049	245.9	Figure 25	15 dB	1.25	$0.14e^{-j204^\circ}$	$1.47e^{j24^\circ}$	24.5%	241.9
$G_D(s)$	5%,12	0.049	245.9	Figure 25	18 dB	0.65	$0.38e^{-j136^\circ}$	$0.38e^{-j44^\circ}$	4.55%	243.4

Table 9. PID controller design parameters, required and achieved performance, identified plant parameters for $G_A(s)$, $G_B(s)$, $G_C(s)$ and $G_D(s)$.

$$\phi'_M = \phi_M + \omega_n D \quad (46)$$

and the controller working angle Θ is to be computed using the relation

$$\Theta = -180^\circ - \phi' + (\phi_M + \omega_n D). \quad (47)$$

The phase delay $\omega_n D$ increases with increasing frequency ω_n of the sinusoidal excitation signal. It is recommended to use the smallest possible added phase $\varphi_D = -\omega_n D$ to lessen the impact of time delay on closed-loop dynamics.

3.4.2.1. Discussion

The time delay D can be easily specified during identification of the critical frequency as a time $D = T_y - T_u$, that elapses since the start of the test at time T_u until time T_y , when the system output starts responding to the excitation signal $u(t)$. A small added phase $\varphi_D = -\omega_n D$ due to time delay can be achieved by choosing the smallest possible ω_n attenuating the effect of D in (47) and subsequently in the PID controller design. Therefore when designing a PID controller for time delayed systems, it is recommended to choose the lowest possible excitation level when using B-parabolas (most frequently $\omega_n/\omega_c = 0.2$ resp. 0.35) and corresponding couples of B-parabolas in **Figure 16**. From the given couple $(\eta_{\max}; t_s)$, ϕ_M is specified using the chosen couple of B-parabolas, however its increased value $\phi_{M'}$ given by (46) is to be supplied in the design algorithm thus minimizing effect of the time delay on closed-loop dynamics.

3.4.2.2. Example 2

Using the sinusoid excitation method, design ideal PID controllers (1a) for a distillation column model given by the transfer function $G_B(s)$

$$G_B(s) = \frac{K_B e^{-D_B s}}{T_B s + 1} = \frac{1.11 e^{-6.5s}}{3.25s + 1}. \quad (48)$$

Control objectives are the same as in Example 1.

3.4.2.3. Solution and discussion

1. Critical frequency of the plant is $\omega_c = 0.3521$ [rad/s]. Based on comparison of critical frequencies, $G_B(s)$ is 500-times slower than $G_A(s)$. Required settling time is $t_s = \tau_s/\omega_c = 12/0.3521$ [s] = 34.08 [s].
2. Because $D_B/T_B = 2 > 1$, the plant is a so-called “dead-time dominant system.” Due to a large time delay, it is necessary to choose the lowest possible excitation frequency ω_n to minimize the added phase $\omega_n D_B$ in (47). Hence, for the required performance $(\eta_{\max 2}; \tau_s) = (5\%; 12)$ (Design No. 2) we choose the $B_{0.2}$ parabolas in **Figure 16** at the lowest possible level $\omega_n/\omega_c = 0.2$ to find $(\phi_{M2}; \omega_{n2}) = (70^\circ; 0.2\omega_c)$. The added phase value is $\omega_{n2} D_B = 0.2\omega_c D_B = 0.2 \cdot 0.3521 \cdot 6.5 \cdot 180/\pi = 26.2^\circ$, hence the phase supplied to the PID design algorithm

is $\phi_{M2} = \phi_{M2} + \omega_{n2}D_B = 70^\circ + 26.2^\circ = 96.2^\circ$ (instead of $\phi_{M2} = 70^\circ$ for a delay-free system). The required performance $(\eta_{\max1}; \tau_s) = (30\%; 12)$ (Design No. 1) can be achieved by choosing $(\phi_{M1}; \omega_{n1}) = (55^\circ; 0.35\omega_c)$ from the $B_{0.35}$ parabolas in **Figure 16** (i.e., $\omega_n/\omega_c = 0.35$). The phase margin $\phi_{M1} = 55^\circ + 45.9^\circ$ supplied into the design algorithm was increased by $\omega_{n1}D_B = 0.35\omega_c D_B = 0.35 \cdot 0.3521 \cdot 6.5 \cdot 180/\pi = 45.9^\circ$ compared with $\phi_{M1} = 55^\circ$ in case of delay-free system.

- Figure 18a** shows that identified points $G_B(j0.35\omega_c) = 1.03e^{-j23^\circ}$ and $G_B(j0.2\omega_c) = 1.09e^{-j13^\circ}$ are located in the quadrant I of the complex plane at the beginning of the frequency response $G_B(j\omega)$ (continuous curve).
- The point $G_B(j0.2\omega_c)$ (Design No. 2) was shifted by the PID controllers to the open-loop amplitude crossover $L_{B2}(j0.2\omega_c) = 1e^{-j110^\circ}$ (dotted Nyquist plot in **Figure 18a**). Note that L_{B2} has the same position in the complex plane as L_{A2} in **Figure 17a**, however at a considerably lower frequency $\omega_{n2B} = 0.2 \cdot 0.3521 = 0.07$ [rad/s] compared to $\omega_{n2A} = 0.8 \cdot 173.216 = 138.6$ [rad/s] ($t_{s2B}^* = 28.69$ [s] is almost 500 times larger than $t_{s2A}^* = 0.0584$ [s] which demonstrates the key role of ω_n in achieving required closed-loop dynamics). The identified point $G_B(j0.35\omega_c)$ (Design No. 1) was moved by the designed PID controller into the amplitude crossover $L_{B1}(j0.35\omega_c) = 1e^{-j125^\circ}$ (dashed Nyquist plot in **Figure 18a**).
- Achieved performances ($\eta_{\max1}^* = 18.6\%$, $t_{s1}^* = 24.78$ [s], dashed line), ($\eta_{\max2}^* = 0.15\%$, $t_{s2}^* = 28.69$ [s], dotted line) in terms of the closed-loop step responses in **Figure 18b** comply with the required performance specification.

3.4.3. Systems with 1st order integrator

Corresponding B-parabolas in **Figures 19–21** were obtained by applying the sinusoid excitation method on a set of benchmark systems with first-order integrator (for a Cartesian product




Figure 18. (a) Open-loop Nyquist plots; (b) closed-loop step responses of the distillation column, required performance $\eta_{\max1} = 30\%$, $\eta_{\max2} = 5\%$ and $\tau_s = 12$.




Figure 19. B-parabolas: (a) $\eta_{\max} = f(\phi_M, \omega_n)$; (b) $\tau_s = \omega_c t_s = f(\phi_M, \omega_n)$ for systems with integrator $\beta = 4$.




Figure 20. B-parabolas: (a) $\eta_{\max} = f(\phi_M, \omega_n)$; (b) $\tau_s = \omega_c t_s = f(\phi_M, \omega_n)$ for systems with integrator $\beta = 8$.

$\phi_{Mj} \times \omega_{nk}$ of the sets (35) and (36), $j = 1 \dots 8$, $k = 1 \dots 6$ and three various ratios T_i/T_d : $\beta = 4, 8$ and 12).

3.4.3.1. Discussion

Inspection of **Figures 19a, 20a** and **21a** reveals that increasing β results in decreasing of the maximum overshoot η_{\max} , narrowing of the B-parabolas of relative settling times $\tau_s = f(\phi_M, \omega_n)$ for each identification level ω_n/ω_c and consequently increasing the settling time.

Consider for example, the $B_{0.95}$ parabolas in **Figures 19b, 20b** and **21b**: if $\phi_M = 70^\circ$ and $\beta = 4$ the relative settling time is $\tau_s = 30$, for $\beta = 8$ it grows up to $\tau_s = 40$, and for $\beta = 12$ even to $\tau_s = 45$. If a 10% maximum overshoot is acceptable for the given system with integrator, then the standard




Figure 21. B-parabolas: (a) $\eta_{\max} = f(\phi_M, \omega_n)$; (b) $\tau_s = \omega_c t_s = f(\phi_M, \omega_n)$ for systems with integrator $\beta = 12$.

interaction PID controller can be used with no need to use the setpoint filter; however a larger settling time is expected.

3.4.3.2. Example 3

Using the sinusoidal excitation method, let us design ideal PID controllers for a flow valve modeled by the transfer function $G_C(s)$ (system with an integrator and a time delay)

$$G_C(s) = \frac{K_C e^{-D_C s}}{s(T_C s + 1)} = \frac{1.3e^{-2.1s}}{s(7.51s + 1)}. \quad (49)$$

The control objective is to guarantee a maximum overshoot of the closed-loop step response $\eta_{\max 1} = 30\%$, $\eta_{\max 2} = 20\%$ and a maximum relative settling time $\tau_s = 20$.

3.4.3.3. Solution and discussion

1. Critical frequency of the plant identified by the Rotach test is $\omega_c = 0.2407$ [rad/s]. Then, the required settling time is $t_s = \tau_s / \omega_c = 20 / 0.2407$ [s] = 83.09[s].
2. For $G_C(s)$ the time delay/time constant ratio is $D_C / T_C = 2.1 / 7.51 = 0.28 < 1$, hence, the influence of the time constant prevails— $G_C(s)$ is a so-called “lag-dominant system” with integrator, therefore B-parabolas are to be chosen carefully. From one side, due to time delay it would be desirable to choose B-parabolas from **Figures 19, 20 or 21** with the lowest identification level $\omega_n / \omega_c = 0.2$. However, the minima of $B_{0.2}$ parabolas in **Figure 19b** (for $\beta = 4$), **Figure 20b** (for $\beta = 8$) and **Figure 21b** (for $\beta = 12$) indicate that the smallest feasible relative settling time $\tau_s = 36.5$ (for $\beta = 4$), $\tau_s = 33$ (for $\beta = 8$) and $\tau_s = 34$ (for $\beta = 12$), which do not satisfy the required value $\tau_s = 20$.

3. The first performance specification $(\eta_{\max 1}; \tau_s) = (30\%; 20)$ can be provided using the $B_{0.35}$ parabolas for $\beta = 12$ (**Figure 21b**) at the level $\omega_n/\omega_c = 0.35$ and for parameters $(\phi_{M1}; \omega_{n1}) = (53^\circ; 0.35\omega_c)$ (Design No. 1), supplying the augmented open-loop phase margin $\phi_{M1} = \phi_{M1} + \omega_{n1}D_C = 53^\circ + 10.1^\circ = 63.1^\circ$ into the PID controller design algorithm. The second performance specification $(\eta_{\max 2}; \tau_s) = (20\%, 20)$ can be achieved using the $B_{0.5}$ parabolas in **Figure 21** for $\beta = 12$ and $\omega_n/\omega_c = 0.5$ and parameters $(\phi_{M2}; \omega_{n2}) = (62^\circ; 0.5\omega_c)$ (Design No. 2). To reject the influence of D_C , instead of $\phi_{M2} = 62^\circ$ the augmented open-loop phase margin $\phi_{M2} = \phi_{M2} + \omega_{n2}D_C = 62^\circ + 14.5^\circ = 76.5^\circ$ was supplied into the PID controller design algorithm.
4. Identified points $G_C(j0.35\omega_c) = 12.7e^{-j122^\circ}$ and $G_C(j0.5\omega_c) = 8.10e^{-j129^\circ}$ are located on the plant frequency response $G_C(j\omega)$ (continuous curve) in **Figure 22a** verifying correctness of the identification.
5. Using the PID controller, the first identified point $G_C(j0.35\omega_c)$ (Design No. 1) was moved into the gain crossover $L_{C1}(j0.35\omega_c) = 1e^{-j127^\circ}$ located on the unit circle M_1 ; this verifies achieving the phase margin $\phi_{M1} = 180^\circ - 127^\circ = 53^\circ$ (dashed Nyquist plot in **Figure 22a**). Achieved performance in terms of the closed-loop step response in **Figure 22b** is $\eta_{\max 1}^* = 29.6\%$, $t_{s1}^* = 81.73[s]$ (dashed line).
6. The second identified point $G_C(j0.5\omega_c)$ (Design No. 2) was moved into $L_{C2}(j0.5\omega_c) = 1e^{-j118^\circ}$ achieving the phase margin $\phi_{M2} = 180^\circ - 118^\circ = 62^\circ$ (dotted Nyquist plot in **Figure 22a**). Achieved performance in terms of the closed-loop step response parameters (**Figure 22b**) $\eta_{\max 2}^* = 19.7\%$, $t_{s2}^* = 82.44[s]$ (dotted line) meets the required specification. Frequency characteristics $L_{C1}(j\omega)$, $L_{C2}(j\omega)$ begin near the negative real half-axis of the complex plane because both open-loops contain a 2nd order integrator.




Figure 22. (a) Open-loop Nyquist plots; (b) closed-loop step responses of the flow valve, required performance $\eta_{\max 1} = 30\%$, $\eta_{\max 2} = 20\%$ and $\tau_s = 20$.

3.4.4. Systems with unstable zero

Consider typical gain margins G_M given by the set

$$\{G_{M_j}\} = \{3dB, 5dB, 7dB, 9dB, 11dB, 13dB, 15dB, 17dB\} \quad (50)$$

for $j = 1 \dots 8$. Let us split (33b) into five equal sections and generate the set of excitation frequencies

$$\{\omega_{nk}\} = \{0.5\omega_c, 0.65\omega_c, 0.8\omega_c, 0.95\omega_c, 1.1\omega_c, 1.25\omega_c\} \quad (51)$$

for $k = 1 \dots 6$. Its elements divided by the plant critical frequency ω_c determine excitation levels

$$\{\sigma_k = \omega_{nk}/\omega_c\} \Rightarrow \{\sigma_k\} = \{0.5, 0.65, 0.8, 0.95, 1.1, 1.25\} \quad (52)$$

for $k = 1 \dots 6$. **Figure 23** shows closed-loop step response shaping using different G_M and ω_n in the PID tuning for the plant (53b) with parameters $T_3 = 0.75$, $\alpha_3 = 1.3$, for four required gain margins $G_M = 5$ dB, 9 dB, 11 dB and 13 dB, and three different excitation levels $\sigma_1 = \omega_{n1}/\omega_c = 0.5$, $\sigma_3 = \omega_{n3}/\omega_c = 0.8$ and $\sigma_5 = \omega_{n5}/\omega_c = 1.1$.

Consider the following benchmark plants

$$G_2(s) = \frac{-\alpha_2 s + 1}{(T_2 s + 1)^{n_2}}, G_3(s) = \frac{-\alpha_3 s + 1}{(s + 1)(T_3 s + 1)(T_3^2 s + 1)(T_3^3 s + 1)}. \quad (53)$$

The proposed method has been applied for each element of the Cartesian product $\omega_{nk} \times G_{M_j}$ of the sets (51) and (50). Significant differences between dynamics of individual control loops under designed PID controllers can be observed for the benchmark systems (53).

Consider the benchmark plants $G_2(s)$ and $G_3(s)$ with following parameters: $G_{2,1}(s)$: $(T_2, n_2, \alpha_2) = (0.75, 8, 0.2)$; $G_{2,2}(s)$: $(1, 3, 0.1)$; $G_{2,3}(s)$: $(0.5, 5, 1)$; $G_3(s)$: $T_3 = 0.5$, $\alpha_3 = 1.3$.

Couples of examined plants $[G_3(s), G_{2,3}(s)]$ and $[G_{2,2}(s), G_{2,1}(s)]$ differ principally by the ratio α/T , which is significant for the closed-loop performance assessment for plants with an unstable zero (for the 1st couple $[\alpha_3/T_3 = 2.6, \alpha_{2,3}/T_{2,3} = 2]$, for the 2nd couple $[\alpha_{2,2}/T_{2,2} = 0.1, \alpha_{2,1}/T_{2,1} = 0.27]$).




Figure 23. Closed-loop step responses of the plant $G_3(s)$ under PID controllers designed for various G_M and ω_n .

According to the ratio α/T unknown plants with an unstable zero can be classified in following two groups [7]:

1. plants with $\alpha/T < 0.3$;
2. plants with $\alpha/T > 0.3$.

With respect to this classification, B-parabolas $\eta_{\max} = f(G_M, \omega_n)$, $\tau_s = f(G_M, \omega_n)$ for nonminimum phase systems with an unstable zero constructed for different open-loop gain margins G_M and excitation levels σ are depicted in **Figure 24** (for $\alpha/T > 0.3$) and in **Figure 25** (for $\alpha/T < 0.3$).

3.4.4.1. Example 4

Using the sinusoid excitation method, ideal PID controllers are to be designed for a heating plant described by the transfer function $G_D(s)$ (a system with an unstable zero)

$$G_D(s) = \frac{K_D(-T_zs + 1)}{(T_Ds + 1)^3} = \frac{0.8(-7.5s + 1)}{(27.5s + 1)^3}. \tag{54}$$

The control objective is to guarantee a maximum overshoot $\eta_{\max1} = 30\%$, $\eta_{\max2} = 5\%$ and maximum relative settling time $\tau_s = 12$.

3.4.4.2. Solution and discussion

1. Critical frequency of the plant identified by the Rotach test is $\omega_c = 0.0467[\text{rad/s}]$, the system is "slow". The required settling time is $t_s = \tau_s/\omega_c = 12/0.0488 = 245.90[\text{s}]$.
2. Because $\alpha/T_D = 7.5/27.5 = 0.27 < 0.3$, the gain margin G_M and the excitation frequency ω_n of the controlled object $G_D(s)$ will be determined using B-parabolas in **Figure 25**. For the required performance $(\eta_{\max1}, \tau_s) = (30\%, 12)$ the appropriate values of gain margin and




Figure 24. B-parabolas: (a) $\eta_{\max} = f(G_M, \omega_n)$; (b) $\tau_s = \omega_c t_s = f(G_M, \omega_n)$ for nonminimum phase systems, $\alpha/T > 0.3$.




Figure 25. B-parabolas: (a) $\eta_{\max} = f(G_M, \omega_n)$; (b) $\tau_s = \omega_c t_s = f(G_M, \omega_n)$ for nonminimum phase systems, $\alpha/T < 0.3$.

excitation frequency are $(G_{M1}, \omega_{n1}) = (15 \text{ dB}, 1.25\omega_c)$, that is “gray parabolas” in Figure 25. Similarly, the performance $(\eta_{\max 2}, \tau_s) = (5\%, 12)$ can be achieved by choosing $(G_{M2}, \omega_{n2}) = (18 \text{ dB}, 0.65\omega_c)$ according to “violet” B-parabolas in Figure 25.

- Examination of the Nyquist plots of the controlled object $G_D(j\omega)$ and the open-loops $L_{D1}(j\omega)$, $L_{D2}(j\omega)$ in Figure 26a reveals that the first identified point $G_D(j1.25\omega_c)$ is located in the quadrant III of the complex plane, and its identification is carried out under a relatively low frequency $1.25\omega_c = 1.25 \cdot 0.0467 = 0.0584 [\text{rad/s}]$, hence no high-frequency




Figure 26. (a) Open-loop Nyquist plots; (b) closed-loop step responses of the heating system, required performance $\eta_{\max 1} = 30\%$, $\eta_{\max 2} = 5\%$ and $\tau_s = 12$.

noise corrupting the excitation and output signals $u(t)$ and $y(t)$, respectively, is expected during identification. If, however, the identification at the excitation level $\omega_n = 1.25\omega_c$ were carried out for a “fast” object with a high value of ω_c , it would be necessary to choose the lowest possible excitation level in order to reject the identification noise. The second identified point $G_D(j0.65\omega_c)$ is placed in the quadrant II of the complex plane.

4. Using the PID controller designed for $(G_{M1}, \omega_{n1}) = (15 \text{ dB}, 1.25\omega_c)$ the point $G_D(j1.25\omega_c)$ was compensated into the target point $L_{D1}(j1.25\omega_c) = [1/10^{G_{M1}/20}]e^{-j180^\circ}$ located on the negative real half-axis where the gain margin G_{M1} of the open-loop $L_{D1}(j\omega)$ (red Nyquist plot) is satisfied. The achieved performance evaluated from the closed-loop step response in **Figure 26b** is $\eta_{\max1}^* = 24.5\%$, $t_{s1}^* = 241.88[s]$.
5. Using the PID controller designed for $(G_{M2}, \omega_{n2}) = (18 \text{ dB}, 0.65\omega_c)$, the point $G_D(j0.65\omega_c)$ was moved to the target point $L_{D2}(j0.65\omega_c) = [1/10^{G_{M2}/20}]e^{-j180^\circ}$ where the gain margin G_{M2} of the open-loop $L_{D2}(j\omega)$ (green Nyquist plot) is satisfied. The achieved performance $\eta_{\max2}^* = 4.55\%$, $t_{s2}^* = 243.42[s]$ evaluated from the closed-loop step response in **Figure 26b** satisfies the control objective.

Time-domain performance requirements specified by the process technologist, identified plant parameters needed for PID controller tuning (for two PID controllers of all four plants $G_A(s)$, $G_B(s)$, $G_C(s)$ and $G_D(s)$) along with specified and achieved performance measure values are summarized in **Table 9**. The asterisk “*” indicates closed-loop performance complying with the required one.

3.5. Robust PID controller design for specified performance

When identifying an uncertain plant, the sinusoidal excitation with the frequency ω_n is repeated for individual parameter changes to obtain a set of points G_i from the set of frequency responses of the uncertain plant

$$G_i(j\omega_n) = |G_i(j\omega_n)|e^{j\arg G_i(\omega_n)} = a_i + jb_i, \tag{55}$$

$i = 1, 2, \dots, N$. Plant parameter changes are reflected in changes of the magnitude and the phase $|G_i(j\omega_n)|$ and $\arg G_i(\omega_n)$, respectively; $i = 1 \dots N$; $N = 2^p$ is the number of identification experiments and p is the number of varying technological quantities of the plant. The nominal model $G_0(j\omega_n)$ is obtained from mean values of the real and imaginary parts of $G_i(j\omega_n)$

$$G_0(j\omega_n) = a_0 + jb_0 = \frac{1}{N} \sum_{i=1}^N a_i + j \frac{1}{N} \sum_{i=1}^N b_i, \tag{56}$$

$i = 1, 2, \dots, N$. Obviously

$$|G_0(j\omega_n)| = \sqrt{a_0^2 + b_0^2} = \frac{1}{N} \sqrt{\left(\left[\sum_{i=1}^N a_i \right]^2 + \left[\sum_{i=1}^N b_i \right]^2 \right)}; \quad \arg G_0(j\omega_n) = \arctg \frac{b_0}{a_0} = \arctg \frac{\sum_{i=1}^N b_i}{\sum_{i=1}^N a_i}, \tag{57}$$

where $\varphi_0(\omega_n) = \arg\{G_0(j\omega_n)\}$. The points G_i represent some elements of the family of plants and can be enclosed by a circle M_G centered in $G_0(j\omega_n)$ with the radius $R_G \equiv R_G(\omega_n)$ corresponding to the maximum distance between $G_i(j\omega_n)$ and $G_0(j\omega_n)$

$$R_G = \max_i \left\{ \sqrt{(a_i - a_0)^2 + (b_i - b_0)^2} \right\}, \quad (58)$$

$i = 1, 2, \dots, N$. Actually, the control law generated by the robust controller $G_{Rrob}(s)$ designed for the nominal point $G_0(j\omega_n)$ performs the mapping

$$\wp : \{R_G \rightarrow R_L : R_L = |G_{Rrob}|R_G\} \quad (59)$$

of the set of identified points $G_i(j\omega_n)$ encircled by M_G with the radius R_G onto the set of points $L_i(j\omega_n)$ delineated by M_L and calculates the radius $R_L \equiv R_L(\omega_n)$ of the dispersion circle M_L which encloses the points $L_i(j\omega_n)$ of the Nyquist plot so as to guarantee fulfillment of the robust performance condition.

A robust PID controller is designed using the sinusoidal excitation method with input data for the nominal model $G_0(j\omega_n)$: $\{|G_0(j\omega_n)|; \varphi_0 = \arg G_0(\omega_n)\}$. Substituting them into (25a), (26a), (29) and (30), the expressions for calculating robust PID controller parameters according to **Table 8** are obtained. Obviously, the phase and gain margins ϕ_M and G_M , respectively, are robust PID controller tuning parameters and at the same time attractive robustness measures [6].

3.5.1. Robust performance condition

Theorem 1 (Sufficient condition for robust performance under a PID controller).

Consider an uncertain continuous-time stable dynamic system described by a nominal model and unstructured uncertainty. The PID controller $G_R(s)$ tuned according to the rules in **Table 8** guarantees robust closed-loop performance if the following conditions are satisfied

$$\varphi_M > \arccos \left(1 - \frac{1}{2} \left(\frac{\chi_L R_G(\omega_n)}{|G_0(j\omega_n)|} + \chi_S \sin \varphi_S \right)^2 \right), \quad G_M > \frac{1 + \chi_L \left[\frac{R_G(\omega_n)}{|G_0(j\omega_n)|} \right]}{1 - \chi_S \left[\frac{G_S - 1}{G_S} \right]}, \quad (60)$$

where ϕ_M and G_M are the required phase and gain margins, respectively, ω_n is the excitation frequency, $\chi_L = R_L^+/R_L$ and $\chi_S = R_S^+/R_S$ are safety factors of radii of the dispersion circles M_L and M_S , respectively, delineating prohibited areas; $R_G(\omega_n)$ is the radius of the dispersion circle at the Nyquist plot of the plant at ω_n , and $G_0(\omega_n)$ is a point at the Nyquist plot of the nominal plant at ω_n . The prohibited area M_S can be defined in terms of ϕ_M or G_M using the expressions $\phi_S = \arcsin(R_S)$ or $G_S = 1/(1 - R_S)$, respectively.

Proof:

The proof is straightforward using **Figures 27** and **28**. If the nominal open-loop $L_0(s) = G_0(s)G_R(s)$ is stable, then according to the Nyquist stability criterion the closed-loop with the uncertain plant will be stable if the distance between L_0 and $(-1, j0)$, that is $|1 + L_0(j\omega_n)|$ is

greater than the sum of the radii $R_L(\omega_n)$ of the circle M_L centered in L_0 , and $R_S(\omega_n)$ of the circle M_S centered in $(-1.0j)$, that is

$$R_L + R_S < |1 + L_0(j\omega_n)|. \tag{61}$$

3.5.1.1. Robust performance condition: phase margin approach

According to **Figure 27**, the distance between $(-1.0j)$ and the open-loop Nyquist plot $L_0(j\omega_n)$ at ω_n , that is $|1 + L_0(j\omega_n)|$ can be calculated by applying the cosine rule to the triangle given by the vertices $(-1.0, L_0)$ (ϕ_M is the phase margin)

$$|1 + L_0| = \sqrt{1 + |L_0|^2 - 2|L_0| \cos \phi_M}. \tag{62}$$

From the principles of the sinusoidal excitation PID controller tuning method results that the robust controller shifts the nominal point of the plant frequency response G_0 to the point L_0 situated on the unit circle. Thus, ω_n becomes the gain crossover frequency. As the point L_0 is situated on the unit circle M_L , the magnitude $|L_0(j\omega_n)|$ equals one, that is $|L_0| = |G_0| |G_R| = 1$, yielding the transformation ratio $|G_R| = |G_0|^{-1}$ between the radii R_G and R_L of the circles M_G and M_L , respectively. The radius R_L of the dispersion circle M_L can be expressed as

$$R_L = R_G |G_R| = \frac{R_G}{|G_0|}. \tag{63}$$

Substituting (62) and (63) in (61) yields the robust performance condition

$$\left(\frac{\chi_L R_G(\omega_n)}{|G_0(j\omega_n)|} + \chi_S R_S \right)^2 < 2 - 2 \cos \phi_M. \tag{64}$$




Figure 27. Dispersion circles M_G and M_L and the prohibited area delineated by the circle M_S for the phase-margin approach.

which after some manipulations is identical to the proven condition (60a). Typical values of safety factors are $\chi_L = 1.1$ and $\chi_S = 1.2$. The value of ϕ_M chosen according to the robust performance condition used in the tuning rules in **Table 1** yields robust PID controller coefficients. The design procedure is illustrated in Section 3.5.1.3.

3.5.1.2. Robust performance condition: gain margin approach

According to **Figure 28**, $|1 + L_0(j\omega_n)|$ is a complement of $|L_0| = |L_0|$ to the unit value. Thus

$$|L_0(j\omega_n)| + |1 + L_0(j\omega_n)| = 1 \Rightarrow |1 + L_0(j\omega_n)| = 1 - |L_0(j\omega_n)|. \quad (65)$$

From the principles of the proposed PID tuning method results that the robust controller shifts the point $G_0(\omega_n)$ of the plant nominal frequency response to L_0 situated on the negative real half-axis of the complex plane. From the relation $|L_0(j\omega_n)| = |G_0(j\omega_n)| |G_R(j\omega_n)| = 1/G_M$ results the ratio $|G_R(j\omega_n)| = 1/[G_M |G_0(j\omega_n)|]$ between the radii R_G and $R_L = |G_R| R_G$ of the circles M_G and M_L , respectively. The radius R_L of the dispersion circle M_L is calculated as follows

$$R_L = R_G |G_R| = \frac{R_G}{G_M |G_0(j\omega_n)|}. \quad (66)$$

Substituting (65) and (66) into the general robust performance condition (61) and considering the safety factors χ_L and χ_S , the following inequality is obtained

$$\frac{G_M - 1}{G_M} > \frac{\chi_L R_G}{G_M |G_0(j\omega_n)|} + \chi_S R_S, \quad (67)$$

which after some manipulations is identical to the proven condition (60b). According to the robust performance condition, the chosen value G_M is substituted into (26a) and robust PID controller parameters are obtained from **Table 8**. ϕ_S and G_S are found from the B-parabolas (**Figures 16, 19–21, 24, 25**) considering $\eta_{\max N}$ and τ_{SN} of the worst-case plant.




Figure 28. Dispersion circles M_G and M_L and the prohibited area delineated by the circle M_S for gain-margin approach.

3.5.1.3. Examples

3.5.1.3.1. Example 5

Consider the plant model $G_A(s)$ from Subsection 3.4

$$G_{A0}(s) = \frac{K_{A0}}{(T_{A0}s + 1)^3} = \frac{1}{(0.01s + 1)^3} \tag{68}$$

to be the nominal model of an uncertain system where K_A and T_A are uncertain parameters varying within $\pm 15\%$ from their nominal values K_{A0} and T_{A0} (i.e., the total dispersion is $\kappa = 30\%$). Let us design a robust PID controller to guarantee $\eta_{\max N} = 30\%$ and a relative settling time $\tau_{sN} = 12$ for the worst-case model of $G_A(s)$.

3.5.1.3.2. Robust PID controller design for the uncertain plant $G_A(s)$ —solution and discussion

1. The measured ultimate frequency of the nominal model is $\omega_{c0} = 173.216[\text{rad/s}]$. From the robust performance condition results $t_{sN} = \tau_{sN}/\omega_c = 12/173.216 = 69.3[\text{ms}]$.
2. For the required performance $(\eta_{\max N}, \tau_{sN}) = (30\%, 12)$ the corresponding values of phase margin and excitation frequency have been selected $(\phi_M, \omega_{n0}) = (50^\circ, 0.5\omega_{c0})$ using the pair of "red" B-parabolas in **Figure 16**. As there are two uncertainties in $G_A(s)$ (K_A and T_A), the number of identification experiments is $N = 2^2 = 4$.
3. For $\omega_{n0} = 0.5\omega_{c0} = 0.5 \cdot 173.21 = 86.61[\text{rad/s}]$, four points of the family of Nyquist plots corresponding to the uncertain plant model were identified using the sinusoidal excitation: $G_{A1}(j\omega_{n0}), G_{A2}(j\omega_{n0}), G_{A3}(j\omega_{n0})$ and $G_{A4}(j\omega_{n0})$ (blue "x" in **Figure 29a**). The nominal point $G_{A0}(j\omega_{n0})$ calculated from the coordinates of all identified points $G_{Ai}(j\omega_{n0}), i = 1, 2, 3, 4$ is




Figure 29. (a) Nyquist plots for $G_A(s)$, $\eta_{\max N} = 30\%$ and $\tau_{sN} = 12$; (b) closed-loop step responses satisfy the required performance $\eta_{\max N} = 30\%$ and $\tau_{sN} = 12$ (upper plot: worst-case plant model; lower plot: nominal plant model).

located on the “blue” Nyquist plot of the nominal model $G_{A0}(j\omega_n)$. The dispersion circle M_C is centered in $G_{A0}(j\omega_{n0})$ with the radius $R_C = 0.199$.

4. The desired robust performance $\eta_{\max N} = 30\%$, $\tau_{sN} = 12$ can be achieved using $\phi_S = 50^\circ$ at the excitation level $\omega_{n0} = 0.5\omega_{c0}$.
5. R.H.S. of the robust performance condition (60a) is $\delta_{0_RP} = 89.39^\circ$, thus the robust performance condition (60a) $\phi_{M>\delta_{0_RP}}$ will be satisfied if choosing for example $\phi_M = 90^\circ$.
6. Using the designed PID controller, the nominal point $G_{A0}(j\omega_{n0})$ is shifted to $L_{A0}(j\omega_{n0}) = G_{A0}(j\omega_{n0})G_{R_rob}(j\omega_{n0}) = 1e^{-j90^\circ}$ on the unit circle M_1 (**Figure 29a**).
7. The smallest phase margin estimated from the location of the worst-case point $L_{AN} = 1.13e^{-j114^\circ}$ is $\phi_{MN} = 66.2^\circ$. The achieved smallest phase margin $\phi_{MN}^+ = 61^\circ$ is given by the intersection of the “red” Nyquist plot and the unit circle M_1 (closest to the negative real half-axis).
8. Radius of the prohibited area $R_S = \sin\phi_S = \sin(50 \cdot 3.14/180) = 0.766/\chi_S = 0.6383$ multiplied by the expansion coefficient $\chi_S = 1.2$, as well as the $\chi_S = 1.1$ -times enlarged radius R_L of the dispersion circle M_L guarantee that none of the open-loop Nyquist plots enters the prohibited area delineated by the M_S circle. The enlarged circles M_L^+ and M_S^+ (dotted plots in **Figure 29a**) are touching, which indicates fulfillment of the robust performance condition.
9. From the closed-loop step response of the worst-case plant model (**Figure 29b**, red plot) results $\eta_{\max N_obtained} = 8.2\%$ and the relative settling time $\tau_{sN_obtained} = \omega_{c0}t_{sN_obtained} = 173.216 \cdot 0.0671 = 11.62$, which proves achievement of the specified performance. Using the phase margin $\phi_M = 90^\circ$ at the identification level $\omega_{n0} = 0.5\omega_{c0}$ (“red” B-parabolas in **Figure 16a**) corresponds to the nominal performance $\eta_{\max 0} = 2\%$ and $\tau_{s0} = 10$. The closed-loop step response in **Figure 29b** (green plot) corresponding to the nominal model satisfies $\eta_{\max 0_obtained} = 0\%$ and $\tau_{s0_obtained} = 173.216 \cdot 0.0469 = 8.12$ as expected.

3.5.1.3.3. Example 6

Consider the plant model from the Subsection 3.4

$$G_{D0}(s) = \frac{K_{D0}(-\alpha_{D0}s + 1)}{(T_{D0}s + 1)^3} = \frac{0.8(-7.5s + 1)}{(27.5s + 1)^3} \quad (69)$$

to be the nominal model of the uncertain plant $G_D(s)$ with parameters K_D , T_D and α_D varying within $\pm 15\%$ from their nominal values K_{S0} , T_{S0} and α_{D0} (the total dispersion is $\kappa = 30\%$). A robust PID controller is to be designed to guarantee specified performance in terms of a maximum overshoot $\eta_{\max N} = 5\%$ and a relative settling time $\tau_{sN} = 12$ for the worst-case model of $G_D(s)$.

3.5.1.3.4. Robust PID controller design for the uncertain plant $G_D(s)$ —solution and discussion

1. The measured ultimate frequency of the nominal model is $\omega_{c0} = 0.0488[\text{rad/s}]$. From the requirements on the nominal closed-loop performance results: $t_s = \tau_{s0}/\omega_c = 12/0.0488 = 245.9[\text{s}]$.

2. For the required performance $(\eta_{\max N}, \tau_{sN}) = (5\%, 12)$ the corresponding values of gain margin and excitation frequency have been selected $(G_M, \omega_n) = (18 \text{ dB}, 0.65\omega_{c0})$ using the pair of "red" B-parabolas in **Figure 25**. As there are three uncertain parameters in $G_D(s)$ (K_D , T_D and α_D), the number of identification experiments is $N = 2^3 = 8$.
3. For $\omega_{n0} = 0.65\omega_{c0} = 0.65 \cdot 0.04880 = 0.03172$ [rad/s], eight points of the family of Nyquist plots corresponding to the uncertain plant model were identified using the sinusoidal excitation: $G_{D1}(j\omega_n) \dots G_{D8}(j\omega_n)$ (depicted by blue "x" in **Figure 30**). The nominal point $G_{D0}(j\omega_n)$ calculated from the coordinates of all identified points $G_{Di}(j\omega_n)$, $i = 1 \dots 8$ is located on the Nyquist plot of the nominal model $G_{D0}(j\omega_n)$ (blue curve) thus proving correctness of the identification. Radius of the dispersion circle M_G centered in the nominal point $G_{D0}(j\omega_{n0})$ with the radius $R_G = 0.164$.
4. The desired robust performance $\eta_{\max N} = 30\%$, $\tau_{sN} = 12$ can be achieved using $\phi_S = 50^\circ$ at the excitation level $\omega_{n0} = 0.5\omega_{c0}$.
5. Using the designed robust PID controller, the nominal point $G_{D0}(j\omega_{n0})$ of the plant is shifted to the point $L_{D0}(j\omega_{n0}) = G_{D0}(j\omega_{n0})G_{R_{\text{rob}}}(j\omega_{n0}) = 0.0841e^{-j180^\circ}$ located on the unit circle. The nominal open-loop Nyquist plot (green plot) crosses $L_{D0}(j\omega_{n0})$ (**Figure 14**), the radius of the circle M_L is $R_L = 0.0400$.
6. The smallest gain margin $G_{MN}^+ = 18.8 \text{ dB}$ is estimated from the position of the worst-case point $L_{DN}(j\omega_{n0}) = 0.112e^{-j197^\circ}$. The achieved smallest gain margin is given by the intersection point of the red Nyquist plot with the negative real half-axis of the complex plane $G_{MN}^+ = 16.9 \text{ dB}$.




Figure 30. (a) Nyquist plots for $G_D(s)$, $\eta_{\max N} = 5\%$ and $\tau_{sN} = 12$; (b) closed-loop step responses with $G_D(s)$ for the required performance $\eta_{\max N} = 5\%$ and $\tau_{sN} = 12$ (upper plot: worst-case plant model; lower plot: nominal plant model).

7. Both the radius of the prohibited area $R_S = (G_S - 1)/G_S = (10^{18/20} - 1)/10^{18/20} = 0.8741/\chi_S = 0.699$ multiplied by the expansion coefficient $\chi_S = 1.2$, as well as the radius R_L of the dispersion circle M_L enlarged $\chi_S = 1.1$ -times guarantee that none of the open-loop Nyquist plots enters the prohibited area delineated by the M_S circle. The enlarged circles M_L^+ and M_S^+ in **Figure 30a** (dotted curves) touch, which indicates fulfillment of the robust performance condition.
8. As $G_M = 21.5$ dB at the excitation level $\omega_{n0} = 0.65\omega_{c0}$ has been considered, according to “pink” B-parabolas in **Figure 25a** nominal performance $\eta_{\max0} = 1.5\%$ and $\tau_{s0} = 21$ is expected. The nominal closed-loop step response in **Figure 30b** (green plot) shows the nominal performance in terms of $\eta_{\max0_obtained} = 0\%$ and $\tau_{s0_obtained} = 0.0488 \cdot 381 = 18.59$ as expected.
9. From the closed-loop step response of the worst-case plant model (**Figure 30b**, red plot) results $\eta_{\max N_obtained} = 4.8\%$ and the relative settling time $\tau_{sN_obtained} = \omega_{c0} t_{sN_obtained} = 0.0488 \cdot 237 = 11.57$ which proves achievement of the specified performance. Using the gain margin $G_M = 21.5$ dB at the excitation level $\omega_{n0} = 0.65\omega_{c0}$ (“pink” B-parabolas in **Figure 25a**) indicates the expected nominal performance $\eta_{\max0} = 1.5\%$ and $\tau_{s0} = 21$. The closed-loop step response in **Figure 30b** (green plot) corresponding to the nominal model satisfies $\eta_{\max0_obtained} = 0\%$ and $\tau_{s0_obtained} = 0.0488 \cdot 381 = 18.59$ as expected.

4. Conclusion

A novel frequency-domain PID design method for performance specified in terms of maximum overshoot and settling time is presented applicable for uncertain systems with parametric uncertainties. One of the main results is developed empirical charts called B-parabolas; this insightful graphical tool is used to transform engineering time-domain performance specifications (maximum overshoot and settling time) into frequency-domain performance measures (phase margin and gain margin). The developed PID design method is based on shaping the closed-loop step response using various combinations of excitation signal frequencies and required phase and gain margins. Using B-parabolas, it is possible to shape time responses of processes with various types of dynamics. By applying appropriate PID controller design methods including the above presented, it is possible to achieve cost-effective control of processes with uncertainties. The presented advanced external harmonic excitation-based design method contributes to improve the unfavorable statistical ratio between the properly tuned to all implemented PID controllers in industrial control loops.

Author details

Štefan Bucz* and Alena Kozáková

*Address all correspondence to: stefan.bucz@stuba.sk

Faculty of Electrical Engineering and Information Technology, Slovak University of Technology, Bratislava, Slovak Republic

References

- [1] Åström KJ, Hägglund T. PID Controllers: Theory, Design and Tuning. 2nd ed. Research Triangle Park: Instrument Society of America; 1995. ISBN 1-55617-516-7
- [2] Åström KJ, Hägglund T. Benchmark Systems for PID Control. In: IFAC Workshop on Digital Control PID'00; 5-7 April 2000; Terrassa, Spain. 2000. pp. 181-182
- [3] Bakošová M, Fikar M. *Riadenie procesov*, Edícia vysokoškolských učebníc, Slovenská technická univerzita v Bratislave, Vydavateľstvo STU v Bratislave. Bratislava, Slovenská republika; 2008. ISBN 978-80-227-2841-6 (in Slovak)
- [4] Balátě J. Automatické řízení. 2. přepracované vydání. Nakladatelství BEN—technická literatura. Praha, Česká republika; 2004. ISBN 80-7300-148-9
- [5] Bialkowski WL. Dreams versus reality: A view from both sides of the gap. Pulp and Paper Canada. 1993;**94**(11):19-27
- [6] Bucz Š. Engineering methods of PID controller tuning for specified performance [doctoral thesis]. Bratislava, Slovenská Republika: Slovenská Technická Univerzita v Bratislave; 2011 (in Slovak)
- [7] Bucz Š, Veselý V, Kozáková A, Kozák Š. A novel PID controller design methodology for specified performance using ultimate plant parameters. In: Proceedings of the 19th World Congress of the International Federation of Automatic Control. IFAC; 2014. pp. 4909-4914. ISBN 978-3-902823-62-5
- [8] Coon GA. How to find controller settings from process characteristics. Control Engineering. May 1956;**3**(5):66-76
- [9] Crolla D, Foster DE, Kobayashi T, Vaughan N. Encyclopedia of Automotive Engineering. United Kingdom: John Wiley and Sons Ltd.; 2015
- [10] Ford RL. The determination of the optimum process-controller settings and their confirmation by means of an electronic simulator. Proceedings of the IEE, Part 2. 1953;**101**(80): pp. 141-155 and pp. 173-177
- [11] Grabbe EM, Ramo S, Wooldrige DE. Handbook of Automation Computation and Control. Vol. 1, 2, 3. New York; 1959–61
- [12] Haalman A. Adjusting controllers for a deadtime process. Control Engineering. 1965; (July):71-73
- [13] Hang CC, Åström KJ. Practical aspects of PID auto-tuners based on relay feedback. In: Proceedings of the IFAC Adaptive control of Chemical Processes Conference, Copenhagen, Denmark; 1988. pp. 153-158
- [14] Harsányi L, Murgaš J, Rosinová D, Kozáková A. Teória automatického riadenia, Edícia skript. Slovenská Technická Univerzita v Bratislave. 1998 (in Slovak)

- [15] Chandrashekar R, Sree RP, Chidambaram M. Design of PI/PID controllers for unstable systems with time delay by synthesis method. *Indian Chemical Engineer Section A*. 2002; **44**(2):82-88
- [16] Chau PC. *Process Control—A First Course with MATLAB*. 1st ed. New York: Cambridge University Press; 2002. ISBN 978-0521002554
- [17] Chen D, Seborg DE. PI/PID controller design based on direct synthesis and disturbance rejection. *Industrial and Engineering Chemistry Research*. 2002;**41**:4807-4822
- [18] Chien KL, Hrones JA, Reswick JB. On the automatic control of generalised passive systems. *Transactions of the ASME*. 1952;**74**(February):175-185
- [19] Kozáková A, Veselý V, Osuský J. Decentralized digital PID design for performance. In: 12th IFAC Symposium on Large Scale Systems: Theory and Applications; 12-14 July 2010; Lille, France. Ecole Centrale de Lille; 2010. ISBN 978-2-915-913-26-2
- [20] Leva A, Maggio M. A systematic way to extend ideal pid tuning rules to the real structure. *Journal of Process Control*. 2011;**21**:130-136
- [21] Leva A, Negro S, Papadopoulos AV. PI/PID autotuning with contextual model parametrisation. *Journal of Process Control*. 2010;**20**:452-463
- [22] Morari M, Zafiriou E. *Robust Process Control*. Englewood Cliffs, New Jersey, USA: Prentice-Hall Inc.; 1989. ISBN 0137821530, 07632
- [23] O'Dwyer A. *Handbook of PI and PID Controllers Tuning Rules*. 2nd ed. London: Imperial College Press; 2006. ISBN 1860946224
- [24] Osuský J, Veselý V, Kozáková A. Robust Decentralized Controller Design with Performance Specification, Vol. 4(1). Kumamoto, Japan: ICIC Express Letters; 2010. pp. 71-76. ISSN 1881-803X
- [25] Padula F, Visioli A. Tuning rules for optimal PID and fractional-order PID controllers. *Journal of Process Control*. 2011;**21**:69-81
- [26] Padula F, Visioli A. On the stabilizing PID controllers for integral processes. *IEEE Transactions on Automatic Control*. 2012;**57**:494-499
- [27] Pettit JW, Carr DM. Self-tuning controller. US Patent No. 4669040; 1987
- [28] Rotach V. *Avtomatizacija nastrojki system upravljenja*. Moskva, Russia: Energoatomizdat; 1984 (in Russian)
- [29] Rotach V. Calculation of the Robust Settings of Automatic Controllers, Vol. 41(10). Moscow, Russia: Thermal Engineering (Russia); 1994. pp. 764-769
- [30] Suyama K. A simple design method for sampled-data PID control systems with adequate step responses. *Proceedings of the International Conference on Industrial Electronics, Control, Instrumentation and Automation*. 1992:1117-1122

- [31] Veronesi M, Visioli A. Performance assessment and retuning of PID controllers. *Industrial and Engineering Chemistry Research*. 2009;**48**:2616-2623
- [32] Veronesi M, Visioli A. An industrial application of a performance assessment and retuning technique for PI controllers. *ISA Transactions*. 2010;**49**:244-248
- [33] Veselý V. Easy tuning of PID controller. *Journal of Electrical Engineering*. 2003;**54**(5–6): 136-139, Bratislava, Slovak Republic. ISSN 1335-3632
- [34] Vilanova R. IMC based robust PID design: Tuning guidelines and automatic tuning. *Journal of Process Control*. 2008;**18**:61-70
- [35] Visioli A. Fuzzy logic based set-point weight tuning of PID controllers. *IEEE Transactions on Systems, Man, and Cybernetics—Part A*. 1999;**29**:587-592
- [36] Visioli A. Tuning of PID controllers with fuzzy logic. *IEE Proceedings—Control Theory and Applications*. 2001;**148**(1):180-184
- [37] Visioli A. *Practical PID control*. Advances in industrial control. Springer-Verlag London Limited; 2006. ISBN 1-84628-585-2
- [38] Visioli A. Research trends for PID controllers. *Acta Polytechnica*. 2012;**52**(5/2012)
- [39] Vítečková M. *Seřízení regulátorů metodou požadovaného modelu*. Ostrava: Skriptum Vysoká škola báňská, Technická univerzita; 1998. ISBN 80-7078-628-0 (in Czech)
- [40] Vítečková M. *Seřízení číslicových i analogových regulátorů pro regulované soustavy s dopravním zpožděním (Digital and analog controller tuning for processes with time delay)*. *Automatizace*. 1999;**42**(2):106-111 (in Czech)
- [41] Vítečková M, Víteček A, Smutný L. Controller tuning for controlled plants with time delay. In: *Preprints of Proceedings of PID'00: IFAC Workshop on Digital Control*; 5-7 April 2000; Terrassa, Spain. 2000. pp. 83-288
- [42] Wang L, Cluett WR. Tuning PID controllers for integrating processes. *IEE Proceedings—Control Theory and Applications*. 1997;**144**(5):385-392
- [43] Wang Y-G, Shao H-H. PID autotuner based on gain- and phase-margin specification. *Industrial and Engineering Chemistry Research*. 1999;**38**:3007-3012
- [44] Wittenmark B. A sample-induced delays in synchronous multirate systems. In: *European Control Conference*; Porto, Portugal. 2001. pp. 3276-3281
- [45] Wojsznis WK, Blevins TL, Thiele D. Neural network assisted control loop tuner. In: *Proceedings of the IEEE International Conference on Control Applications*, Vol. 1; USA: 1999. pp. 427-431
- [46] Xue D, Chen Y, Atherton DP. *Linear Feedback Control: Analysis and Design with MATLAB*. SIAM Press; 2007. ISBN 978-0-898716-38-2

- [47] Yu C-C. Autotuning of PID Controllers. A Relay Feedback Approach. 2nd ed. Springer-Verlag London Limited; 2006. ISBN 1-84628-036-2
- [48] Ziegler JG, Nichols NB. Optimum settings for automatic controllers. ASME Transactions. 1942;**64**:759-768
- [49] Zhuang M, Atherton DP. Automatic tuning of optimum PID controllers. IEE Proceedings Part D: Control Theory and Applications. 1993;**140**(3):216-224. ISSN 0143-7054

